

BL3100C-8-RR100 Rail Road Signal Source SPECIFICATIONS

INPUT

Voltage: C-8: 115/230 VAC +/- 10%, Single Phase.
Frequency: 57 - 253 Hz

OUTPUT

Voltage: 120 VAC, Single Phase,
Isolated and Floating.
Frequency: 100 Hz, +/- 0.25 Hz
Power: 3 KVA
Current: 25 Amps
Current Crest Factor: 3:1
Power Factor: 100% of rated output into
any power factor load
Distortion: 2.0% Typical THD
Load Regulation: $\pm 0.7\%$ No Load to Full Load
Line Regulation: $\pm 0.1\%$ for $\pm 10\%$ Line Change
Efficiency: 85% typical



CONTROL CIRCUIT

External Sync: Synchronize AC output with 115 VAC external input.

PROTECTIVE CIRCUITS / INDICATORS

Input: Main circuit breaker and surge arrestors.

Constant Current Mode: Overload automatically causes voltage fold-back to provide maximum current without distorting output waveform.

Overload Protection: Short Circuit overload electronically disables output to protect load. Automatic reset upon overload removal.

Thermal Protection: Internal temperature sensor prevents heat damage.

Output: Surge arrestors & transformer isolated.

Meters: Digital Meters for Volts, Amps & Frequency

Continued on second page.....

MECHANICAL SPECIFICATIONS

Dimensions:	Two high strength 19" rack mount chassis, each: 7.0"H x 22"D.
Weight:	225lbs
Operating Temperature:	0 to 55° C.
Cooling:	Internal fans.
Input connections:	Screw type terminals.
Output connections:	Screw type terminals.
Sync connections:	Screw type terminals

OPTIONS:

A: Alarms, Contact closure & Indicator

1. Inv OK - Loss of Inverter output.
2. Sync - Loss of sync input
3. Lock - Out of phase condition between Inverter output and Sync Input
4. Over Temp - Over Temperature

ID: Input Turn on Delay

RC: Ruggedized and **Conformally** coat PC boards

S10: Slides, heavy duty, full set for each chassis

World Headquarters

80 Cabot Court Hauppauge, NY 11788
(631)435-0410 (800)874-6727 Fax(631)951-4341

BEHLMAN

e-mail: sales@behlman.com
Web-site: www.behlman.com

West Coast Office

4532 Telephone Road Suite 103 Ventura, CA 93003
(805)642-0660 (800)456-2006 Fax(805)642-0790
BL3KRR.08 Oct 04