

CERTIFICATE G83/1

Engineering Recommendation

Issuing company : Mastervolt B.V.
Address : Snijdersbergweg 93
Postal code, place : 1105 AN Amsterdam
Country : The Netherlands

Electrical apparatus : Photovoltaic Inverter with HF-transformer
Trademark : MASTERVOLT

Type designation	Rated power	Max. Export capability
Sunmaster XL15K	15000W	15750W
XL5000 GBR power module	5000W	5250W

Test details

Power quality

Harmonic current emissions as per BS EN 61000-3-12 A

Voltage Fluctuations and Flicker as per BS EN 61000-3-3 A

Power Factor

DC injection under normal operation and protection function

Under / Over Frequency switch off

Under / Over Voltage switch off

Loss Of Mains Test

Reconnection Time

Mastervolt declares that Sunmaster XL inverters, fitted with power modules with GBR setting, (as indicated on the serial number labels) are compliant with the specifications set by the G83/1 engineering recommendation version 015D, issued by Electricity Association Services, London.

Mastervolt R&D department
Amsterdam, 04-04-2008



Ing. D.R. Bassie.

Test results

1. POWER QUALITY

Harmonic current emissions as per BS EN 61000-3-12-Class A								
Harmonic	2 nd	3 rd	5 th	7 th	9 th	11 th	13 th	15 th ... 39 th
Limit (Amp.)	1.08	2.3	1.14	0.77	0.4	0.33	0.21	0.15 x (15/n)
Test value	0.07	0.45	0.10	0.13	0.14	0.15	0.16	1.13
% of fund.	0.32	1.97	0.45	0.57	0.60	0.66	0.70	4.96

Voltage fluctuations and Flicker as per BS EN 61000-3-3 Class A				
Harmonic	Starting	Stopping	Running	
Limit	4%	4%	$P_{st} = 1.0$	$P_{rf} = 0.65$
Test value	Max 2%	Max 2%	Max 0.582 in 10 min.	Max 0.582 in 2 hrs.

	DC injection			Power Factor		
G83/1 limit	20mA, tested at three levels			0.95 lag - 0.95 lead at three voltage levels at P_{rated}		
Test level	10%	50%	100%	212V	230V	248V
Test value	<6mA	<8mA	<12mA	0.998	0.997	0.996

	DC injection protection	
Parameter	DC inj [mA]	Time[s]
Actual setting	+/- 100 mA	1s
Test value	+/- 100 mA	570ms

2. UNDER / OVER FREQUENCY SWITCH OFF

	Under Frequency Switch Off						Over Frequency Switch Off					
Parameter	Frequency [Hz]			Time [s]			Frequency [Hz]			Time [s]		
G83/1 limit	47 Hz			0.5s			50.5 Hz			0.5s		
Output power	10%	50%	100%	10%	50%	100%	10%	50%	100%	10%	50%	100%
Actual setting	47 Hz	47 Hz	47 Hz	0.5s	0.5s	0.5s	50.5 Hz	50.5 Hz	50.5 Hz	0.5s	0.5s	0.5s
Trip value	47.01 Hz	46.99 Hz	47.00 Hz	499ms	495ms	499ms	50.51 Hz	50.51 Hz	50.49 Hz	489ms	487ms	495ms

3. UNDER / OVER VOLTAGE SWITCH OFF

	Under Voltage Switch Off						Over Voltage Switch Off					
Parameter	Voltage [V]			Time [s]			Voltage [V]			Time [s]		
G83/1 limit	207V			1.5s			264V			1.5s		
Output power	10%	50%	100%	10%	50%	100%	10%	50%	100%	10%	50%	100%
Actual setting	207V	207V	207V	1.5s	1.5s	1.5s	264V	264V	264V	1.5s	1.5s	1.5s
Trip value	207.6V	207.9V	206.4V	1.49s	1.48s	1.48s	264.3V	263.8V	263.5V	1.47s	1.48s	1.48s

4. LOSS OF MAINS TEST

Method used	Frequency shift		
Output power level	10% P_{rated}	50% P_{rated}	100% P_{rated}
G83/1 limit	0.5s	0.5s	0.5s
Trip setting	0.5s	0.5s	0.5s
Trip value	470ms	370ms	401ms

5. RECONNECTION TIME MEASUREMENT

Reconnection time	Under / over Voltage	Under / over Frequency	Loss of Mains
Minimum value	180s	180s	180s
Actual setting	180s	180s	180s
Recorded value	180s	180s	180s

6. FAULT LEVEL CONTRIBUTION

As Photovoltaic SSEGs are inverter connected, they are deemed to automatically comply with regulations and no further tests are required

7. SELF MONITORING - SOLID STATE SWITCHING

Not applicable as electro-mechanical relays are used.