

1.0 EXECUTIVE SUMMARY

Aseania Linear District Cooling System Sdn Berhad ("Company") operates the Bandar Perda district cooling plant since end of 2005 for over 1 ½ years. Installed capacity of plant is currently 2,000RT. Under the plant capacity development plan, the district cooling plant is mapped to be built up by 3 Phases with estimated total development cost of RM94 million.

| Phases | Description | Cumulative plant capacity | Year in service | Capital expenditure RM million |
|----------|--|---------------------------|-----------------|--------------------------------|
| Phase 1 | Two (2 nos) 1,000 RT centrifugal chillers | 2,000RT | End-2005 | 26.0 |
| Phase 2A | Two (2 nos) 2,100 RT centrifugal chillers | 6,200RT | 2008 | 40.0 |
| Phase 2B | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 11,600RT | 2009 | |
| Phase 3 | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 17,000RT | 2011 | 24.0 |
| | | | | 90.0 |

Based on the financial projections prepared, the following are the estimated financial parameters of the district cooling business

| | | |
|--|---|-------------------|
| Capital expenditure budget | | RM90 million |
| Contribution from developer(s) | | (RM10 million) |
| Net investment | : | RM80 million |
| Equity payback period (from first year of investment) | : | 13.7 years |
| Net present value (@9% disc.rate) | : | +ve RM3.4 million |
| Internal rate of return | : | 9.7% |
| Operational profit (breakeven) | : | Year 5 onwards |
| Average EBITDA margin | : | 34% |

The following are the key construction milestones:

| Key milestones | Phase 2A | Phase 2B | Phase 3 |
|--|----------|----------|---------|
| 1 Ice tank tender & construction | N.A. | | |
| 2 M&E Installation tender & installation | | | |
| 3 Procurement (chillers, cooling towers, pumps, ice coils) | | | |
| 4 Control & Instrumentation | | | |
| 5 Testing & Commissioning | | | |

[Remainder of the page is left blank intentionally]

2.0 OVERVIEW OF BANDAR PERDA DEVELOPMENT



Endorsed by the Penang Regional Development Authority (PERDA), this 456-acre development at the prime land in central Seberang Perai, Northern Peninsular Malaysia, named after the authority – Bandar Perda, is a self contained township.


Bandar Perda, touted to be the governmental administrative capital of the North, is a futuristic integrated one-stop regional center designed to hub the Indonesia-Malaysia-Thailand Growth Triangle (IMT-GT). When completed, the township is projected to house a population of 70,000 and will be accessible to a catchment area of 2.5 million people.

Within the RM3 billion-master plan of Bandar Perda are the following developments:

- (i) Head office for Majlis Pebandaran Seberang Prai (MPSP), local council for Seberang Prai;
- (ii) Northern head office for the Inland Revenue Board of Malaysia;
- (iii) Head quarters of the Royal Police Force headquarters
- (iv) Head quarters of the Fire & Rescue Department
- (v) Medical Center & Health Park
- (vi) De Rendezvouz Mall –food & entertainment mall
- (vii) Mega Mall
- (viii) Bus cum Taxi Terminal
- (ix) Puncak Aseania (the head office of the developer of Bandar Perda)
- (x) Aseania Mall (integrated commercial complex with offices, hotel & shopping points)
- (xi) Bazaar Perdana (wet & dry market)
- (xii) The largest district cooling facility with ice-based external melt thermal storage in the region.



Figure 1: Master Layout of Bandar Perda Development



3.0 CURRENT DISTRICT COOLING OPERATION


3.1 Overview of the District Cooling Plant



Designed, built, operated and full owned by Linear Corporation Berhad, the plant will have eventual rated capacity of 17,000 refrigeration tons featuring 48,000 ton-hours of ice based thermal storage.

| | |
|---|---|
| Owner | : Aseania Linear District Cooling System Sdn Bhd (100% owned by Linear) |
| Location | : Bandar Perda, Seberang Prai |
| Rated output capacity of cooling plant | : 17,000 tons |
| Water supply/return temperatures | : 34°F/54°F (1.1°C/12.2°C) |
| Description of project | : 22,000 square foot, single level, stand-alone building that contains two (2 nos) 2,000 ton and two (2 nos) 2,100 ton centrifugal water chillers, four 1,500 ton dual evaporator chillers and 48,000 ton-hours of external melt ice-based thermal storage. Connecting all clients' premises is the completed 7.0 kilometers in length supply & return insulated piping network. |

3.2 Current Plant Configuration




Summary of current plant capacity:

- a) Chillers - 2 x 1,000RT
- b) Cooling towers - 2 x 1,055 HRT


Full details of the equipment installed are enclosed in [Appendix 1](#).

3.3 Installed Chilled Water Piping Network


Below is an overview of the chilled water piping network installed in Bandar Perda.




Note: Pink lines represent main distribution piping network installed in Bandar Perda




Drawing 1: Piping Network Connecting to Perda Fire Brigade




Drawing 2: Piping Network Connecting to Perda Police HQ



Drawing 3: Piping Network From District Cooling Plant to Police HQ & Fire Brigade



Drawing 4: Piping Network from District Cooling Plant to De Rendezvous & Inland Revenue Board's Office



Drawing 5: Continuation of Piping Network from IRB Office to MPSP Office.

4.0 PLANT DEVELOPMENT PROGRAM

4.1 District Cooling Plant Development Program

Bandar Perda district cooling plant is currently mapped to be developed in three phases as follows:

| Phases | Description | Cumulative plant capacity | Year in service | Capital expenditure RM'000*** |
|----------|--|---------------------------|-----------------|-------------------------------|
| Phase 1 | Two (2 nos) 1,000 RT centrifugal chillers | 2,000RT | End-2005* | 25,631 |
| Phase 2A | Two (2 nos) 2,100 RT centrifugal chillers | 6,200RT | 2008 | 44,796 |
| Phase 2B | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 11,600RT | 2009** | |
| Phase 3 | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 17,000RT | 2011** | 23,968 |

* Completed phase.

** Actual implementation of the phasing depends on the physical development in Bandar Perda.

*** Capital expenditure for Phase 2 & 3 are based on estimates provided by TES Avenue Sdn Bhd.

4.2 Current Contracted Capacity

- (i) MPSP (partial of 1,350RT)
- (ii) IRB (290RT)
- (iii) De' Rendezvous (partial of 750RT)
- (iv) Police HQ (325 RT)

4.3 New Development In Bandar Perda

| | Completion | Required RT |
|-----------------------------|------------|-------------|
| • Mega Mall | 2008 | 5,600 |
| • Hospital | 2008 | 800 |
| • Stage 2 (Future building) | 2008^ | 1,500 |
| • Stage 2 (New Building-1) | 2009^ | 2,000 |
| • Stage 3 (New Building-2) | 2010^ | 2,500 |
| • Stage 3 (New Building-3) | 2011^ | 2,000 |
| • Stage 3 (New Building-4) | 2012^ | 2,500 |
| • Stage 3 (New Building-5) | 2012^ | 2,500 |

^ Depending on the actual development in Bandar Perda by Aseania Development Sdn Bhd

[Remainder of the page is left blank intentionally]

4.4 Future Capital Expenditure Budget

4.4.1 Phase 2

(a) Phase 2A

| Item | Description | Size | Quantity | Estimates RM |
|------|---|-------|----------|-----------------|
| 1 | Glycol Chillers -TR | - | - | - |
| | Centrifugal Chillers-RT | 2,100 | 2 | 5,040 |
| 2 | Ice Coils - TrH | - | - | - |
| 3 | Cooling Towers-75 HP | | 4 | 680 |
| 4 | Pumps | | | 500 |
| 5 | Control System | | | 1,200 |
| 6 | Mechanical Services Installation | | | |
| a | Piping installation including piping , Chilled water piping, condenser water piping, valves etc. | | | 2,300 |
| b | i)To hoist & move chillers,pumps, cooling towers into position and piping connection ii) including piping connection. iii) Plant ventilation duct installtion iv) Cleaning & flushing of piping v)Testing & Commissioning | | | 750 |
| c | Ice Tank Insulation works | | | - |
| 7 | Glycol Solution | | | - |
| 8 | External Underground Piping Installation | | | |
| a | Underground piping works | | | 1,950 |
| b | Piling & concrete support | | | 350 |
| d | Other works | | | 50 |
| e | Replace 300mm dia. Pipe ~ 300m | | | 1,700 |
| 9 | Electrical Services Installation | | | |
| | VCB, Transformers, MSB, cabling etc | | | 2,120 |
| | Motor Control Board | | | 480 |
| | Electrical Cabling works For Mech. Installation | | | 200 |
| 10 | Ice Tank Construction | | | |
| a | Piling | | | 806 |
| b | Ice Tank Construction | | | - |
| c | Provisional Sum For Roof | | | - |
| 11 | Provisional Sum For | | | |
| a | Piping To Hospital | | | 335 |
| b | Fiber Optic Control Cable Manholes | | | 140 |
| | | | | 18,601 |
| 12 | Contribution Charges To TNB | | | 200 |
| 13 | Consultant Fees | | | 720 |
| | | | | 19,521 |

(b) Phase 2B

| Item | Description | Size | Quantity | Estimates RM'000 |
|------|--|--------|----------|---------------------|
| 1 | Glycol Chillers -TR Centrifugal Chillers-RT | 1,500 | 2 | 8,700 |
| 2 | Ice Coils - TrH | 24,000 | | 3,421 |
| 3 | Cooling Towers-75 HP | | | 519 |
| 4 | Pumps | | | 500 |
| 5 | Control System | | | 1,200 |
| 6 | Mechanical Services Installation | | | |
| a | Piping installation including piping , Chilled water piping, condenser water piping, valves etc. i)To hoist & move chillers,pumps, cooling towers | | | |
| b | into position and piping connection ii) including piping connection. iii) Plant ventilation duct installtion iv) Cleaning & flushing of piping v)Testing & Commissioning | | | |
| c | Ice Tank Insulation works | | | 3,900 |
| 7 | Glycol Solution | | | 500 |
| 8 | External Underground Piping Installation | | | 450 |
| a | Underground piping works | | | |
| b | Piling & concrete support | | | |
| d | Other works | | | |
| e | Replace 300mm dia. Pipe ~ 300m | | | |
| 9 | Electrical Services Installation | | | |
| | VCB, Transformers, MSB, cabling etc | | | 2,120 |
| | Motor Control Board | | | 600 |
| | Electrical Cabling works For Mech. Installation | | | 100 |
| 10 | Ice Tank Construction | | | |
| a | Piling | | | |
| b | Ice Tank Construction | | | 900 |
| c | Provisional Sum For Roof | | | 400 |
| | | | | 23,310 |
| | Contingency 5% | | | 1,165 |
| b | Fiber Optic Control Cable Manholes | | | 24,475 |
| 11 | Contribution Charges To TNB | | | 200 |
| 12 | Consultant Fees | | | 600 |
| | | | | 25,275 |

(c) Phase 3

| Item | Description | Size | Quantity | Estimates RM'000 |
|------|--|--------|----------|---------------------|
| 1 | Glycol Chillers -TR Centrifugal Chillers-RT | 1,500 | 2 | 8,700 |
| 2 | Ice Coils - TrH | 24,000 | | 3,421 |
| 3 | Cooling Towers-75 HP | | | 519 |
| 4 | Pumps | | | 500 |
| 5 | Control System | | | 1,000 |
| 6 | Mechanical Services Installation | | | |
| a | Piping installation including piping , Chilled water piping, condenser water piping, valves etc. i)To hoist & move chillers,pumps, cooling towers | | | |
| b | into position and piping connection ii) including piping connection. iii) Plant ventilation duct installtion iv) Cleaning & flushing of piping v)Testing & Commissioning | | | |
| c | Ice Tank Insulation works | | | 3,500 |
| 7 | Glycol Solution | | | 500 |
| 8 | External Underground Piping Installation | | | 450 |
| a | Underground piping works | | | 975 |
| b | Piling & concrete support | | | 175 |
| d | Other works | | | 25 |
| e | Replace 300mm dia. Pipe ~ 300m | | | |
| 9 | Electrical Services Installation | | | |
| | VCB, Transformers, MSB, cabling etc | | | 1,600 |
| | Motor Control Board | | | 600 |
| | Electrical Cabling works For Mech. Installation | | | 100 |
| 10 | Ice Tank Construction | | | |
| a | Piling | | | |
| b | Ice Tank Construction | | | |
| c | Provisional Sum For Roof | | | |
| | Contingency 5% | | | 22,065 |
| | | | | 1,103 |
| b | Fiber Optic Control Cable Manholes | | | 23,168 |
| 11 | Contribution Charges To TNB | | | 200 |
| 12 | Consultant Fees | | | 600 |
| | | | | 23,968 |

4.5 Construction Schedule

The key milestones of the DCP development are below:

| | Key milestones | Phase 2A | Phase 2B | Phase 3 |
|---|--|----------|----------|---------|
| 1 | Ice tank tender & construction | N.A. | | |
| 2 | M&E Installation tender & installation | | | |
| 3 | Procurement (chillers, cooling towers, pumps, ice coils) | | | |
| 4 | Control & Instrumentation | | | |
| 5 | Testing & Commissioning | | | |

5.0 COMMERCIAL ARRANGEMENT FOR ADDITIONAL SUPPLY OF CHILLED WATER

5.1 Chilled Water Tariff

Below are the chilled water tariffs applicable for the new development and existing customers

| Terms discussed between Aseania Dev. & AEON (as informed by Steven Ong, GM of Aseania Dev.) | Other Existing Customers and New Customers Chilled Water Supply Terms |
|--|---|
| ✓ Chilled water rate: RM0.40/ton-hour | ✓ Chilled water rate: RM0.548/ton-hour |
| ✓ No adjustments | ✓ Adjustment every 3-year (5%) |
| ✓ Adjustment for utility tariff increase with modification for PBA rates | ✓ Adjustment when utility tariff increases |
| ✓ Penalty when chilled water temperature reaches 12.1 deg.C for 1-hour: RM25,000/hr | ✓ Penalty for failure to supply not quantified |

The chilled water supply for the Aseania Mall is to be entered into in a back-to-back arrangement between Aseania Development and the Company and then between Aseania Development and AEON Co (M) Berhad (as the end-user).

Payment of usage of services will made direct by AEON Co (M) Berhad to the Company.

5.2 Cooperation Agreement with Aseania Development

In view of the potential differences between the negotiated terms for chilled water supply as experienced in the Aseania Mega Mall (Jusco), a cooperation agreement is being finalized to capture the basis of cooperation between the development and the Company.

The agreement captures the roles of the developer and the Company in respect of chilled water supply in Bandar Perda. A copy of the Cooperation Agreement is enclosed [Appendix 2](#) for perusal.

Salient Terms:



- i) Aseania Development is to ensure that all future buildings in Bandar Perda is designed for exclusive usage of chilled water from the district cooling plant for air-conditioning purposes;
- ii) Aseania Development further undertakes that when terms of chilled water has been finalized, the relevant building has to constructed in such a manner that they are exclusively connected to the district cooling plant for chilled water supply for the purposes of air-conditioning and cooling purposes;
- iii) Aseania Development is to pay the Company a sum equivalent to twenty five per cent (25%) of the Cost of Conventional Cooling System ("Contribution Sum") of all the buildings to be connected to the district cooling plant. Cost of Conventional Cooling System is set at RM2,100 per RT or such number to be mutually agreed;
- iv) Payment of the Contribution Sum shall be made in tandem with development of the relevant buildings;
- v) Compensation shall be payable for the delay of payment of the Contribution Sum by the Developer after the expiry of Contribution Sum Payment Schedule to be calculated at the rate of Eight and a Half Percent (8.5%) per annum based on a 365-day year on any sum unpaid up to the date of full settlement;
- vi) In the event any of the negotiated chilled water supply terms deviates from the prevailing standard terms, Aseania Development undertakes to provide reasonable adjustments on the Contribution Sum for any compromise made by the Company;
- vii) In addition the Contribution Sum, a connection fees calculated at RM100 per RT connected to buildings is payable by Aseania Development to the Company within fourteen (14) days from the completion of testing and commissioning of the connection of each buildings to the plant; and
- viii) Future development identified by Aseania Development Sdn Bhd for the years 2007 to 2009 are:



| Item | Buildings | Estimated Built-up Area(ft ²) | Estimated Commencement | Estimated Completion |
|------|-----------------------------|---|------------------------|----------------------|
| 1 | Aseania Mega Mall (Jusco) | 800,000 | Mar-07 | Dec-07 |
| 2 | Hospital | 185,000 | Mar-07 | Jun-08 |
| 3 | 1 Block of 16 Storey Office | 180,000 | Nov-07 | Nov-09 |
| 4 | Bomba HQ | 65,000 | Jun-08 | Dec-09 |
| 5 | Aseania Mall (Phase 2) | 350,000 | Sep-08 | Jun-10 |
| | Total | 1,580,000 | | |

6.0 FINANCIAL PROJECTIONS

With Jusco being the one of the most successful household name for shopping mall in Malaysia, may bring positive spin off for more commercial buildings development in Bandar Perda. The following evaluations is based certain assumptions which are set out in the financial model printouts ([Appendix 3](#)).

| | | |
|--|---|-------------------|
| Capital expenditure budget | | RM90 million |
| Contribution from developer(s) | | (RM10 million) |
| Net investment | : | RM80 million |
| Equity payback period (from first year of investment) | : | 13.7 years |
| Net present value (@9% disc.rate) | : | +ve RM3.4 million |
| Internal rate of return | : | 9.7% |
| Operational profit (breakeven) | : | Year 5 onwards |
| Average EBITDA margin | : | 34% |





Key Assumptions:

1. Development of the Bandar Perda requires the following cooling load by the specified timeframe

| Phases | Description | Cumulative plant capacity | Year in service | Capital expenditure RM million |
|----------|--|---------------------------|-----------------|--------------------------------|
| Phase 1 | Two (2 nos) 1,000 RT centrifugal chillers | 2,000RT | End-2005 | 26.0 |
| Phase 2A | Two (2 nos) 2,100 RT centrifugal chillers | 6,200RT | 2008 | 40.0 |
| Phase 2B | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 11,600RT | 2009 | |
| Phase 3 | Two (2 nos) 1,500 RT dual evaporator chillers with 24,000 ton-hours of ice thermal storage | 17,000RT | 2011 | 24.0 |
| | | | | 90.0 |

2. Financing of the DCP is based on the following structure and costs

| | Phase 1 | Phase 2 | Phase 3 | Total |
|------------|----------------|----------------|----------------|---------------|
| | RM'000 | RM'000 | RM'000 | RM'000 |
| Equity | 13,631 | 30,396 | 11,968 | 55,995 |
| Borrowings | 12,000 | 14,400 | 12,000 | 38,400 |
| | <i>25,631</i> | <i>44,796</i> | <i>23,968</i> | <i>94,395</i> |

Borrowings are based on the cost of 8.30% per annum, with repayment over 7 years after 2 years of deferment of principal repayment.

3. Chilled water tariff applicable are based on the normal tariff structure applicable at Bandar Perda (subject to normal adjustment of 5% every 3 years), except for that for Mega Mall.
4. Contribution from Aseania Development Sdn Bhd is as per the Cooperation Agreement.
5. Utility costs per ton-hour of chilled water produced is assumed to be RM0.25/ton-hour and RM0.016/ton-hour for electricity and water respectively. No tariff adjustment is factored into the projection as it is assumed that any tariff adjustment will be effectively pass-on to customers based on the prevailing chilled water agreement with existing customers.
6. Maintenance of the plant is assumed to be at 2.5% of the respective phase of district cooling plant development subject to inflation of 3.5% per annum.

Appendix 1

Schedule of currently installed equipment specifications:

1.0 Chiller (2 in nos)

| | |
|-----------------------------------|-------------------------------------|
| Maker | CARRIER |
| Country of Manufacturer | USA |
| Model | 19XR-8081566ELH52S |
| Type | Hermetic Centrifugal Liquid Chiller |
| Total Cooling Capacity (RT) | 1000 |
| Input Power Required (kW) | 665 |
| kW/RT | 0.665 |
| Overall Dimensions L X W X H (mm) | 5455 X 1645 X 2750 |
| Type of Anti-Vibration Mounting | Spring Isolators |
| Total Operating Weight (Kg) | 23826 |

1.1 Refrigerant Compressor (2 in nos)

| | |
|-----------------------------------|----------------------|
| Maker | CARRIER |
| Country of Manufacturer | USA |
| Type | Hermetic Centrifugal |
| Model | 566 |
| Type of Refrigerant Used | 134a |
| Total Cooling Capacity (Btu/hr) | |
| Suction Temperature (°C) | 4.1 |
| Condensing Temperature (°C) | 37.2 |
| Speed (Rpm) | VFD |

1.2 Compressor Motor (2 in nos)

| | |
|--------------------------------|----------------|
| Maker | CARRIER |
| Country of Manufacturer | USA |
| Type | Hermetic Drive |
| Model | EL |
| Horse Power Rating | |
| Speed (Rpm) | VFD |
| Volts/Phase/Hz | 400/3/50 |
| Rated Full Load Current (Amps) | 1072 |

1.3 Water Cooled Condenser (2 in nos)

| | |
|------------------------------------|--------------|
| Maker | CARRIER |
| Country of Manufacturer | USA |
| Type | Shell & Tube |
| Model | 81 |
| Total Heat Rejection Capacity, MBH | 14269 |
| No. of Tubes | 1080 |
| No. of Passes | 2 |
| Diameter of Tube (inches) | 0.025 |
| Tubing Material | Copper |
| Fouling Factor | 0.00025 |
| Water Flowrate (gpm) | 3000 |
| Water Entering Temperature (°F) | 88 |
| Water Leaving Temperature (°F) | 97.5 |
| Pressure Drop (ft water) | 13.8 |

1.4 **Water Cooler (2 in nos)**

| | |
|---------------------------------|--------------|
| Maker | CARRIER |
| Country of Manufacturer | USA |
| Type | Shell & Tube |
| Model | 80 |
| No. of Tubes | 829 |
| No. of Passes | 2 |
| Diameter of Tube (inches) | 0.025 |
| Tubing Material | Copper |
| Fouling Factor | 0.0001 |
| Water Flowrate (gpm) | 1711.2 |
| Water Entering Temperature (°F) | 54 |
| Water Leaving Temperature (°F) | 40 |
| Pressure Drop (ft water) | 9.5 |

2.0 **Distribution Pump (2 in nos)**

| | |
|----------------------------------|---------------------------|
| Maker | Bell & Gossett |
| Country of Manufacture | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type | VSCS |
| Model | 10 x 12 x 17L |
| Casing Material | Cast Iron |
| Impeller Material | Bronze |
| Shaft Material | Stainless Steel |
| Mechanical Seal Yes/No | Yes |
| Impeller Diameter (inches) | 17.13 |
| Capacity (usgpm) | 3000 |
| Total Head (ft water) | 200 |
| Pump Speed (Rpm) | 1450 |
| Pump Efficiency (%) | 85 |
| Pump BHP at specified conditions | 171.93 |
| Casing Design Pressure (psi) | 175 |

-
Pump Motor (2 in nos)

| | |
|--------------------------------------|---------------------------|
| Maker | Brook Crompton |
| Country of Manufacturer | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type/Model | Squirrel Cage Induction |
| Name Plate HP | 250 |
| Rated Speed (Rpm) | 1450 |
| Volts/Phase/Hz | 415/3/50 |
| Rated Full Load Current (Amp) | 311 |
| Enclosure/Protection | TEFC / IP 55 |
| Class of Insulation | F |
| Power Factor at Specified Conditions | NA |
| Efficiency at Specified Conditions | 85 |
| Type of anti-vibration mounting | Spring Isolators |
| Operating Weight (Kg) | NA |
| Dimensions L X W X H (mm) | NA |

3.0 Chilled Water Pump (2 in nos)

| | |
|----------------------------------|---------------------------|
| Maker | Bell & Gossett |
| Country of Manufacture | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type | VSCS |
| Model | 8 x 10 x 11.75L |
| Casing Material | Cast Iron |
| Impeller Material | Bronze |
| Shaft Material | Stainless Steel |
| Mechanical Seal Yes/No | Yes |
| Impeller Diameter | 10.875 |
| Capacity (usgpm) | 1714 |
| Total Head (ft water) | 62 |
| Pump Speed (Rpm) | 1450 |
| Pump Efficiency (%) | 82 |
| Pump BHP at specified conditions | 33.24 |
| Casing Design Pressure (psi) | 175 |

-

Pump Motor (2 in nos)

| | |
|--------------------------------------|---------------------------|
| Maker | Brook Crompton |
| Country of Manufacturer | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type/Model | Squirrel Cage Induction |
| Name Plate HP | 40 |
| Rated Speed (Rpm) | 1450 |
| Volts/Phase/Hz | 415/3/50 |
| Rated Full Load Current (Amp) | 52 |
| Enclosure/Protection | TEFC / IP 55 |
| Class of Insulation | F |
| Power Factor at Specified Conditions | NA |
| Efficiency at Specified Conditions | 82 |
| Type of anti-vibration mounting | Spring Isolators |
| Operating Weight (Kg) | NA |
| Dimensions L X W X H (mm) | NA |

4.0 Condenser Water Pump (2 in nos)

| | |
|----------------------------------|---------------------------|
| Maker | Bell & Gossett |
| Country of Manufacture | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type | VSCS |
| Model | 10 x 12 x 13L |
| Casing Material | Cast Iron |
| Impeller Material | Bronze |
| Shaft Material | Stainless Steel |
| Mechanical Seal Yes/No | Yes |
| Impeller Diameter | 12.625 |
| Capacity (usgpm) | 3000 |
| Total Head (ft water) | 90 |
| Pump Speed (Rpm) | 1450 |
| Pump Efficiency (%) | 85 |
| Pump BHP at specified conditions | 81.58 |
| Casing Design Pressure (psi) | 175 |

Pump Motor (2 in nos)

| | |
|--------------------------------------|---------------------------|
| Maker | Brook Crompton |
| Country of Manufacturer | UK |
| Local Agent | Water-Line System Sdn Bhd |
| Type/Model | Squirrel Cage Induction |
| Name Plate HP | 100 |
| Rated Speed (Rpm) | 1450 |
| Volts/Phase/Hz | 415/3/50 |
| Rated Full Load Current (Amp) | 127 |
| Enclosure/Protection | TEFC / IP 55 |
| Class of Insulation | F |
| Power Factor at Specified Conditions | NA |
| Efficiency at Specified Conditions | 85 |
| Type of anti-vibration mounting | Spring Isolators |
| Operating Weight (Kg) | NA |
| Dimensions L X W X H (mm) | NA |

5.0 **Water Filtration Pump (1 in no)**

| | |
|----------------------------------|--------------------------|
| Maker | GRUNDFOS |
| Country of Manufacture | UK |
| Local Agent | |
| Type | Centrifugal |
| Model | E 125 x 100 x 260 |
| Casing Material | Cast Iron |
| Impeller Material | Bronze |
| Shaft Material | Stainless Steel |
| Mechanical Seal Yes/No | Yes |
| Impeller Diameter | 243 mm |
| Flow Rate (gpm) | 136.4 m ³ /hr |
| Total Head (ft water) | 18 m |
| Pump Speed (Rpm) | 1457 |
| Pump Efficiency (%) | 88.9 |
| Pump BHP at specified conditions | |

Pump Motor (1 in no)

| | |
|--|----------------------|
| Maker | Western Electric |
| Country of Manufacturer | UK |
| Local Agent | |
| Type/Model | 3 Ph Induction Motor |
| Name Plate HP | 11 Kw |
| Rated Speed (Rpm) | 1456 |
| Volts/Phase/Hz | 415/3/50 |
| Rated Full Load Current (Amp) | 20.7 |
| Stator Temperature Cut Out Protection Yes/No | |
| Class of Insulation | F |
| Power Factor at Specified Conditions | 0.84 |
| Efficiency at Specified Conditions | 88.9 |
| Type of anti-vibration mounting | Rubber Mounting |
| Operating Weight (Kg) | |
| Dimensions L X W X H (mm) | |

6.0 **Condenser Water Filtration Pump (1 in no)**

| | |
|----------------------------------|--------------------------|
| Maker | GRUNDFOS |
| Country of Manufacture | UK |
| Local Agent | |
| Type | Centrifugal |
| Model | E 150 x 125 x 260 |
| Casing Material | Cast Iron |
| Impeller Material | Bronze |
| Shaft Material | Stainless Steel |
| Mechanical Seal Yes/No | Yes |
| Impeller Diameter | 255 mm |
| Flow Rate (gpm) | 218.2 m ³ /hr |
| Total Head (ft water) | 18.3 |
| Pump Speed (Rpm) | 1450 |
| Pump Efficiency (%) | 90.1 |
| Pump BHP at specified conditions | |

-
Pump Motor (1 in no)

| | |
|--|----------------------|
| Maker | Western Electric |
| Country of Manufacturer | UK |
| Local Agent | |
| Type/Model | 3 Ph Induction Motor |
| Name Plate HP | 15 Kw |
| Rated Speed (Rpm) | 1457 |
| Volts/Phase/Hz | 415/3/50 |
| Rated Full Load Current (Amp) | 27.6 |
| Stator Temperature Cut Out Protection Yes/No | |
| Class of Insulation | F |
| Power Factor at Specified Conditions | 0.83 |
| Efficiency at Specified Conditions | 90.1 |
| Type of anti-vibration mounting | Rubber Mounting |
| Operating Weight (Kg) | |
| Dimensions L X W X H (mm) | |

7.0 **Cooling Tower (2 in nos)**

| | |
|----------------------------------|-----------------------|
| Maker | BAC Baltimore Aircoil |
| Country of Manufacturer | Malaysia |
| Type | Gross Flow |
| Model | 331055 |
| Heat Rejection Capacity (Btu/hr) | |
| Water Flowrate (gpm) | 3000 |
| Water Temperature In (°F) | 97.5 |
| Water Temperature Out (°F) | 88 |
| Fan Type | Axial |
| Number of Fans | 1 (each) |
| Fan Diameters (inches) | 156 |
| Fan Speed (Rpm) | |
| Fan BHP | |
| Fan Capacity (Cfm) | 290,050 |
| Fan Motor Maker | TECO |
| Fan Motor HP | 75 |
| Fan Motor Efficiency % | |
| Housing Material | Fiber FRP |

| | |
|---------------------------------|---|
| Infill Material | PVC |
| Basin Material | Galvanized Epoxy Coating |
| Fan Blade Material | Fiber Glass and Mild Steel |
| Drift Loss (gpm) | |
| Evaporation Loss (gpm) | |
| Type of Water Treatment | |
| Type of Anti-Vibration Mounting | |
| Operating Weight (Kg) | 44,600 |
| Dimension L X W X H (inches) | 13' - 11 1/8" X 24' - 0 1/2" X 19' - 0 3/8" |

8.0 **Heat Exchanger MPSP (02 in nos)**

| | |
|-----------------------------------|-------------------|
| Required Coling Capacity (RT) | 1350 |
| Designed Pressure (bar) | 10 |
| Heat Exchanged (Btu/h) | 16,269,434 |
| Plate Type | NT150LHV |
| Total Heat Transfer Area (ft²) | 4925.13 |
| Number of Plates / Frames | 281 |
| Plate Thickness (In) | 0.02 |
| Surface Margin (%) | 7 |
| Plate Material | AISI316 |
| Gasket Material / Type | NBR / Glueless |
| Internal Flow (passes x channels) | 1 x 140 |
| Overall Dimensions L x W x H (mm) | 2696 x 640 x 2137 |
| Operating Weight (kg) | 2804 |
| Main Pipe Size (mm) | 200 |
| Secondary Temperature In (°F) | 54 |
| Secondary Temperature Out (°F) | 44 |
| Calculated Secondary Flow (gpm) | 3240 |
| Pressure Drop (psi) | 11.17 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 1,621,850 |
| Volume Flow (US gpm) | 3240 |
| Primary Temperature In (°F) | 38 |
| Primary Temperature Out (°F) | 52 |
| Calculated Primary Flow (gpm) | 2314.3 |
| Pressure Drop (psi) | 5.94 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 1,158,482 |
| Volume Flow (US gpm) | 2314 |

8.1 **Heat Exchanger LHDN (01 in no)**

| | |
|-----------------------------------|-------------------|
| Required Coling Capacity (RT) | 270 |
| Designed Pressure (bar) | 10 |
| Heat Exchanged (Btu/h) | 3,248,606 |
| Plate Type | NT150LHV |
| Total Heat Transfer Area (ft²) | 856.16 |
| Number of Plates / Frames | 99 |
| Plate Thickness (In) | 0.02 |
| Surface Margin (%) | 7 |
| Plate Material | AISI304 |
| Gasket Material / Type | NBR / Glueless |
| Internal Flow (passes x channels) | 1 x 49 |
| Overall Dimensions L x W x H (mm) | 1496 x 640 x 2137 |
| Operating Weight (kg) | 1549 |

| | |
|---------------------------------|---------|
| Main Pipe Size (mm) | 100 |
| Secondary Temperature In (°F) | 54 |
| Secondary Temperature Out (°F) | 44 |
| Calculated Secondary Flow (gpm) | 648 |
| Pressure Drop (psi) | 10.73 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 324,370 |
| Volume Flow (US gpm) | 648 |
| Primary Temperature In (°F) | 38 |
| Primary Temperature Out (°F) | 52 |
| Calculated Primary Flow (gpm) | 462.9 |
| Pressure Drop (psi) | 6 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 231,296 |
| Volume Flow (US gpm) | 462 |

8.2 **Heat Exchanger Rendezvous (01 in no)**

| | |
|-----------------------------------|-------------------|
| Required Coling Capacity (RT) | 750 |
| Designed Pressure (bar) | 10 |
| Heat Exchanged (Btu/h) | 9,029,115 |
| Plate Type | NT150LHV |
| Total Heat Transfer Area (ft²) | 2762.66 |
| Number of Plates / Frames | 315 |
| Plate Thickness (In) | 0.02 |
| Surface Margin (%) | 7 |
| Plate Material | AISI304 |
| Gasket Material / Type | NBR / Glueless |
| Internal Flow (passes x channels) | 1 x 157 |
| Overall Dimensions L x W x H (mm) | 2996 x 640 x 2940 |
| Operating Weight (kg) | 3039 |
| Main Pipe Size (mm) | 150 |
| Secondary Temperature In (°F) | 54 |
| Secondary Temperature Out (°F) | 44 |
| Calculated Secondary Flow (gpm) | 1800 |
| Pressure Drop (psi) | 11.02 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 901,028 |
| Volume Flow (US gpm) | 1800 |
| Primary Temperature In (°F) | 38 |
| Primary Temperature Out (°F) | 52 |
| Calculated Primary Flow (gpm) | 1285.7 |
| Pressure Drop (psi) | 5.94 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 643,323 |
| Volume Flow (US gpm) | 1285 |

8.2 **Heat Exchanger Police Station (01 in no)**

| | |
|--------------------------------|-----------|
| Required Coling Capacity (RT) | 325 |
| Designed Pressure (bar) | 10 |
| Heat Exchanged (Btu/h) | 2,916,018 |
| Plate Type | NT150LHV |
| Total Heat Transfer Area (ft²) | 767.9 |
| Number of Plates / Frames | 89 |
| Plate Thickness (In) | 0.02 |

| | |
|-----------------------------------|-------------------|
| Surface Margin (%) | 7 |
| Plate Material | AISI304 |
| Gasket Material / Type | NBR / Glueless |
| Internal Flow (passes x channels) | 1 x 44 |
| Overall Dimensions L x W x H (mm) | 1796 x 640 x 2087 |
| Operating Weight (kg) | 1693 |
| Main Pipe Size (mm) | 150 |
| Secondary Temperature In (°F) | 54 |
| Secondary Temperature Out (°F) | 44 |
| Calculated Secondary Flow (gpm) | 780 |
| Pressure Drop (psi) | 12.61 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 390,445 |
| Volume Flow (US gpm) | 780 |
| Primary Temperature In (°F) | 38 |
| Primary Temperature Out (°F) | 52 |
| Calculated Primary Flow (gpm) | 557.1 |
| Pressure Drop (psi) | 7 |
| Working Pressure Inlet (psig) | 72.5 |
| Mass Flow (lb/h) | 278,857 |
| Volume Flow (US gpm) | 557 |



> Ice coils & Make-up Water Tank location



> Chiller No. 1



> Chiller No. 2



> Cooling towers



> Distribution Pumps



> Water filtration pump