



- | LEGEND: | |
|---------|--|
| 1 | LM-6000 GAS TURBINE GENERATOR |
| 2 | LM-6000 EXHAUST STACK |
| 3 | LM-6000 AUXILIARY SKID |
| 4 | LM-6000 TURBINE REMOVAL |
| 5 | LM-6000 GENERATOR REMOVAL |
| 6 | LM-6000 15 KV BREAKER |
| 7 | LM-6000 LUBE OIL FIN FAN COOLER |
| 8 | LM-6000 MODULAR CONTROL BUILDING |
| 9 | LM-6000 OVERHEAD CABLE TRAY |
| 10 | LM-6000 GAS COMPRESSOR SHED |
| 11 | LM-6000 FG COMPRESSORS W/ FIN FANS |
| 12 | LM-2500 GAS TURBINE GENERATOR |
| 13 | LM-2500 EXHAUST STACK |
| 14 | LM-2500 HYDRAULIC START SKID |
| 15 | LM-2500 TURBINE REMOVAL |
| 16 | LM-2500 GENERATOR REMOVAL |
| 17 | LM-2500 15 KV BREAKER |
| 18 | LM-2500 MODULAR CONTROL BUILDING |
| 19 | LM-2500 GAS COMPRESSOR SHED |
| 20 | LM-2500 FG COMPRESSORS W/ FIN FANS |
| 21 | SPRINT SKID |
| 22 | WATER INJECTION SKID |
| 23 | FUEL GAS/FILTER SKID |
| 24 | WATER INJECTION SKID (LIQUID FUEL) |
| 25 | LIQUID FUEL INJECTION PUMP (2 EACH) |
| 26 | DEMIN WATER TANK (21,000 GAL EACH) |
| 27 | DEMIN WATER FORWARDING PUMPS |
| 28 | DEMIN WATER TREATMENT BUILDING |
| 29 | DEMIN WATER FILTER |
| 30 | AIR INSTRUMENT DRYER PACKAGE |
| 31 | FIRE WATER TIE POINT |
| 32 | WASTE OIL INTERCONNECT TIE POINT |
| 33 | RAW WATER SUPPLY INTERCONNECT TIE POINT |
| 34 | WASTE WATER INTERCONNECT TIE POINT |
| 35 | NATURAL GAS SUPPLIED TIE POINT (BY OWNER) |
| 36 | FUTURE COOLING TOWER / CHILLER |
| 37 | CENTRIFUGE PACKAGES (BY OWNER), |
| 38 | EMERGENCY BLACK START (BY OWNER) |
| 39 | FUTURE AUX TRANSFORMER |
| 40 | FOAM GENERATOR SHED |
| 41 | EXISTING WATER TANK |
| 42 | ESD GAS VALVE |
| 43 | DEAD END TOWER |
| 44 | AUXILIARY TRANSFORMER (4160 V) |
| 45 | AUXILIARY TRANSFORMERS (480 V) |
| 46 | OILY WATER SEPARATOR |
| 47 | TREATED LIQUID FUEL TANK (25,000 GALS) |
| 48 | RAW LIQUID FUEL TANK (50,000 GALS) |
| 49 | LIQUID FUEL UNLOADING AREA |
| 50 | LIQUID FUEL UNLOADING AREA PUMP |
| 51 | LIQUID FUEL FORWARDING PUMP |
| 52 | OFFICES/CONTROL BUILDING |
| 53 | MCC ROOM |
| 54 | ROAD |
| 55 | PROPERTY BOUNDARY EXISTING CONCRETE RETAINING WALL |
| 56 | PIPE RACK |
| 57 | TREATED LF PIPE MOUNTED ON PIPE RACK |
| 58 | NG PIPE MOUNTED ON PIPE RACK |
| 59 | RAW DFO LINE TO RAW STORAGE TANK |
| 60 | WASTE WATER PIPE MOUNTED ON PIPE RACK |
| 61 | WASTE OIL PIPE MOUNTED ON PIPE RACK |
| 62 | DEMIN WATER TO DFO CENTRIFUGE |
| 63 | NOT USED |
| 64 | EXISTING SUBSTATION AREA |
| 65 | LM-6000 GSU |
| 66 | LM-6000 69 KV LIVE TANK BREAKER |
| 67 | NEW 69 KV OVERHEAD TRANSMISSION LINE |
| 68 | NEW TRANSMISSION POLE LOCATION |
| 69 | 138 KV TRANSMISSION TANGENT POLE |
| 70 | 138 KV/416 KV 25 MVA TRANSFORMER |
| 71 | 138 KV/480 V 2 MVA TRANSFORMER |
| 72 | EXISTING 2 EACH LM-2500 GSU TRANSFORMERS |
| 73 | UNDER GROUND CABLE (TANGENT POLE TO LM-2500 GSU) |
| 74 | LM-6000 DISCONNECT SWITCH (HORIZONTAL MOUNTED) |
| 75 | 138 KV FEEDER CABLE |
| 76 | LF FILTER SKIDS |
| 77 | RO TANK (5,000 GALS) |
| 78 | SERVICE AIR COMPRESSOR |
| 79 | PROPERTY BOUNDARY NEW CONCRETE RETAINING WALL |

																														
REVISION																														
CUSTOMER INFORMATION																														
© COPYRIGHT, 2008, ProEnergy Services, All Rights Reserved. THIS DRAWING IS THE PROPRIETARY AND/OR CONFIDENTIAL PROPERTY OF ProEnergy Services AND IS LOANED IN STRICT CONFIDENCE WITH THE UNDERSTANDING THAT IT WILL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR MANNER FOR WHICH IT IS LOANED. IT SHALL BE IMMEDIATELY RETURNED ON DEMAND, AND IS SUBJECT TO ALL OTHER TERMS AND CONDITIONS OF ANY WRITTEN AGREEMENT OR PURCHASE ORDER WHICH INCORPORATES OR RELATES TO THIS DRAWING.																														
<table><tr><th>NO.</th><th>DATE</th><th>BY</th><th>APPRO</th><th>REVISION LOCATION OF ALL EQUIPMENT</th><th>DESCRIPTION</th><th>REVISIONS</th></tr><tr><td>B</td><td>10/12/09</td><td>LES</td><td></td><td></td><td></td><td></td></tr></table>										NO.	DATE	BY	APPRO	REVISION LOCATION OF ALL EQUIPMENT	DESCRIPTION	REVISIONS	B	10/12/09	LES											
NO.	DATE	BY	APPRO	REVISION LOCATION OF ALL EQUIPMENT	DESCRIPTION	REVISIONS																								
B	10/12/09	LES																												
<table><tr><td>DRAWN</td><td>LES</td><td>7/12/09</td></tr><tr><td>CHECK</td><td></td><td></td></tr><tr><td>DESIGN</td><td>LES</td><td>7/12/09</td></tr><tr><td>PROJ ENGR</td><td></td><td></td></tr><tr><td>PROJ MGR</td><td></td><td></td></tr><tr><td>QA MGR</td><td></td><td></td></tr><tr><td>SCALE</td><td>1"=60'</td><td>SIZE D</td></tr></table>										DRAWN	LES	7/12/09	CHECK			DESIGN	LES	7/12/09	PROJ ENGR			PROJ MGR			QA MGR			SCALE	1"=60'	SIZE D
DRAWN	LES	7/12/09																												
CHECK																														
DESIGN	LES	7/12/09																												
PROJ ENGR																														
PROJ MGR																														
QA MGR																														
SCALE	1"=60'	SIZE D																												
<div><p>ProEnergy EPC SERVICES</p></div>																														
<p>907 S DETROIT SUITE 140 TULSA, OKLAHOMA 74120 OFFICE 907-629-6100 FAX 918-270-2839 www.proenergyservices.com</p>																														
<p>ProEnergy EPC Services, LLC</p>																														
<p>GENERAL ARRANGEMENT PLOT PLAN TACOMA POWER PLANT</p>																														
<table><tr><td>CAD/CDS</td><td>DWG NO.</td><td>SH NO.</td><td>REV</td></tr><tr><td>0906</td><td>10--001</td><td>2</td><td>B</td></tr></table>										CAD/CDS	DWG NO.	SH NO.	REV	0906	10--001	2	B													
CAD/CDS	DWG NO.	SH NO.	REV																											
0906	10--001	2	B																											
VENDUELA																														