

FUEL GAS MODULE EQUIPMENT PARTS LIST**[4448-LD-001]**

	REVISION LETTER	GE ALTERATION NOTICE NUMBER
GE PURCHASE ORDER NUMBER: 180336823		
GE ORDER DRAWING NUMBER: 377A3277		
GE MLI / CC NUMBER: 0991 / 7EA		

KVAERNER PROCESS SYSTEMS**PERTH, AUSTRALIA**

2	6/3/02	AB	AB		Revised to GE Comments
1	27/2/02	JF	AB		Revised to GE Comments
0	1/2/02	JF	AB		Issued for Approval
REV	ISSUE DATE	PREP'D	CHECKED	KPS APP.	DESCRIPTION

GE Power GenerationGENERAL ELECTRIC COMPANY
Schenectady, NYDT- 1N
DM GR0730**VENDOR SUPPLIED DRAWING**GE NOT TO REVISE. GE REVISION LEVEL IS AS SHOWN ON THIS APPLIQUÉ.
THIS DOCUMENT IS FILED UNDER THE GE DRAWING NUMBER.THIS DOCUMENT SHALL BE REVISED IN ITS ENTIRETY. ALL SHEETS OF THIS DOCUMENT ARE THE SAME REVISION LEVEL
AS INDICATED IN THIS VENDOR SUPPLIED DRAWING APPLIQUÉ.

FIRST MADE FOR: ML-7A1PEA234

1 of 5

GE SIGNATURES	DATE	GE DRAWING NUMBER	REV.
CHECKED:		378A5570	-
ISSUED:			

The information provided in this manual is subject to change without notice, and does not claim to detail all possible operational variations in which the equipment is capable of, nor does this document claim to provide information for every possible situation to be met within the scope of installation, operation and maintenance. In the event further information is required, or particular problems arise which are not sufficiently explained to satisfy the purchasers purposes, the matter should be brought to the attention of the GE Company.

KVAERNER PROCESS SYSTEMS, Building C 283-291 Treasure Road, WELSHPOOL WA 6106 PHONE: (08) 9351-9711 FAX: (08) 9356-1704

[4448-LD-001]

FUEL GAS MODULE EQUIPMENT PARTS LIST**[4448-LD-001]**

GE ORDER DRAWING #: 377A3277										
GE MLI/CC: 0991/7EA										
ITEM #	ITEM DESC	DEVICE #	QTY	GE REF#	COMPONENT SUPPLIER / ADDRESS	COMPONENT SUPPLIER PART #	SKID SUPPLIER PART#	PUB. TITLE	Pub No	Pub Rev
0300	Purge Valve	VA13-3 VA13-4 20PG -3,4 VA36-3,4 33PG-5,6,7,8	2	586A2260P006	Fisher Marshalltown, Iowa 50158	P-S ESA-600-6DS A/C	4448-0300	Instruction Manual CV500 Valve D102512X012 PSP Instructions (Posi-seal 1035/A41 Control Valve Package) ERRATA SHEET GO Switch, Switchpak Models 41-44 Operation ASCO 3-Way Piston Valve Installation & Maintenance Instructions ENVIRO-SEAL Packing System – Butterfly Valves, Form 5320	Form 5302 1035- A41 1035- A41PSP 8321	4/01 03/9 8 04/9 9
0302	Pressure Regulator	VPR54-2	1	356A1933P002	Fisher Marshalltown, Iowa 50158	FS64-29/V1/G8	4448-0302	Instructions Manual 64 Series Regulators		
0304	Solenoid Valve	VA13-16 20VG-3	1	363A5550P006	Fisher Marshalltown, Iowa 50158	ESA 65-4/A EFHG8321 G1	4448-0304	Installation & Maintenance Instructions Series 8016G	Form V6583R 6	
0200	Solenoid Dump Valve	20FG-1	1	354A1617P001	Ruggles- Klingemann PO Box 1435 Seabrook NH 03874	533T	4448-0200	Maintenance for R-K Fig.		
0203	Orifice Nipple	N/A	1	256A1133P012	KPS	Orifice	4448-0203	N/A		
0507	Heater	23VS-1	1	371A5678P004	Ruffneck Heaters 2827 Sunridge Blvd. N.E. Calgary, Alberta T1Y6G1 Canada	CXC4NO	4448-0507	Owners Manual CX1 ProVector Series	N/A	
0504	Acoustic/ Weather Hood	N/A	1	373A7662P001	KPS	7EA Hood	4448-0504	N/A		
0505	Atmosphere Detector	45HA-7 45HA-8	2	315A2708P001	General Monitors 26776 Simpatica Circle Lake Forrest CA 92630	10252 10014-1 18-00-822	4448-0505	Sensors & Accessory Equipment		
0508	Temperature Switch	26VS-1	1	363A5545P003	ITT 28150 Industry Dr. Valencia CA 91355	132T4S409-003	4448-0508			

FIRST MADE FOR: ML-7A1PEA234**GE DRAWING NUMBER****REV.****378A5570**

-

The information provided in this manual is subject to change without notice, and does not claim to detail all possible operational variations in which the equipment is capable of, nor does this document claim to provide information for every possible situation to be met within the scope of installation, operation and maintenance. In the event further information is required, or particular problems arise which are not sufficiently explained to satisfy the purchasers purposes, the matter should be brought to the attention of the GE Company.

KVAERNER PROCESS SYSTEMS,

Building C 283-291 Treasure Road WELSHPOOL WA 6106 PHONE: (08) 9351-9711 FAX: (08) 9356-1704

[4448-LD-001]

FUEL GAS MODULE EQUIPMENT PARTS LIST**[4448-LD-001]**

GE ORDER DRAWING #: 377A3277										
GE MLI/CC: 0991/7EA										
ITEM #	ITEM DESC	DEVICE #	QTY	GE REF#	COMPONENT SUPPLIER / ADDRESS	COMPONE NT SUPPLIER PART #	SKID SUPPLIER PART#	PUB. TITLE	Pub No	Pub Rev
0512	Motor Exhaust Fan	23VL-1 23VL-2 88VL-1 88VL-2	2	363A4383P002	Airkinetics 11595 Kelly Rd. FT. Myers FL. 33908	125 LFB	4448-0512	Storage, Installation & Maintenance Instructions	N/A	
0600	Duplex Strainer	N/A	1	361A6263P031	Vee Bee Old Wharf Rd. Stourbridge West Midlands UK	VB361A6263P031	4448-0600	Duplex Strainer 6" Dwg. #GE4422P031 Dual In-Line Strainers Installation and Maintenance Manual	DIL-IOM.DO C	2
0601	Duplex Stainer Basket	N/A	2	361A6263P251	Vee Bee Old Wharf Rd. Stourbridge West Midlands UK	VB361A6263P251	4448-0601	SEE 0600		
0602	Fuel Gas Stop Speed Ratio Valve # 300 4"	VSR-1 96SR-1 96SR-2 VH5-1 FH7-1 90SR-1	1	371A6407P014	Woodward Governor Company 1000 East Drake Rd. Fort Collins CO 80522	9904-511	4448-0602	Operation Manual 26093		B
0604	Fuel Gas Control Valve # 300 3"	VGC-1 VGC-3 96GC-1 96GC-2 96-GC-5 96GC-6 VH5-2 VH5-4 FH8-1 FH8-3 65GC-1 65GC-3	2	371A6408P006	Woodward Governor Company 1000 East Drake Rd. Fort Collins CO 80522	9904-507	4448-0604	Operation Manual 26094A		D
0605	Fuel Gas Control Valve # 300 2"	VGC-2 96GC-3 96GC-4 VH5-3 FH8-2 65GC-2	1	371A6408P003	Woodward Governor Company 1000 East Drake Rd. Fort Collins CO 80522	9904-506M	4448-0605	Operation Manual 26094A		
0607	Solenoid Valve	20VG-1	1	358A7624P001	ASCO Florham Park NJ 07932	HV272241-001	4448-0607	Installation and Maintenance Instructions	N/A	
9000	Light Fixture	DL-51 AL-87 AL-88	3	302A4577P002	Crouse-Hinds Industries PO Box 4999, Syracuse, New York 13221	EVXC210	4448-9000	Operating Instructions, Pendant Lighting for Hazardous areas series EV	N/A	
9001	Switch	ASW-44 ASW-43	2	360A7433P003	Crouse-Hinds Industries PO Box 4999, Syracuse, New York 13221	ESD2130-GB	4448-9001	Installation & Maintenance Information	IF 899	08/99
9005	Latch, Cylinder	N/A	4	362A1240P001	KPS	4448-9005	4448-9005	N/A		

FIRST MADE FOR: ML-7A1PEA234**GE DRAWING NUMBER****REV.****378A5570**

-

The information provided in this manual is subject to change without notice, and does not claim to detail all possible operational variations in which the equipment is capable of, nor does this document claim to provide information for every possible situation to be met within the scope of installation, operation and maintenance. In the event further information is required, or particular problems arise which are not sufficiently explained to satisfy the purchasers purposes, the matter should be brought to the attention of the GE Company.

KVAERNER PROCESS SYSTEMS,

Building C 283-291 Treasure Road WELSHPOOL WA 6106 PHONE: (08) 9351-9711 FAX: (08) 9356-1704

[4448-LD-001]

FUEL GAS MODULE EQUIPMENT PARTS LIST**[4448-LD-001]**

GE ORDER DRAWING #: 377A3277										
GE MLI/CC: 0991/7EA										
ITEM #	ITEM DESC	DEVICE #	QTY	GE REF#	COMPONENT SUPPLIER / ADDRESS	COMPONE NT SUPPLIER PART #	SKID SUPPLIER PART#	PUB. TITLE	Pub No	Pub Rev
	Locking									
9006	Hinge, Bearing	N/A	8	219B6009P001	KPS	4448-9006	4448-9006	N/A		
9011	Pressure Switch	63VL-3 63VL-4 63VL-5	3	314A5443P008	Dwyer PO Box 373 Michigan City, Indiana 46360	1950-0	4448-9011	Installation and Operating Instructions	N/A	12/9 3
9200	3-Way Valve	N/A	3	361A6239P003	Parker Hannifin 2651 Alabama Hwy. 21 N. Jacksonville AL 36265	4F- B6SPKR-V- SSP	4448-9200	HB Series Ball Valve Installation Instructions	N/A	
9201	Needle Valve	N/A	1	371A6460P001	Noshok 1010 West Bagley Rd. Berea, Ohio 44017	NS70645	4448-9201	N/A		
9202	Pressure Gauge	HG	1	315A2970P105	Ashcroft 250 E. Main St. Stratford Co	45-1379- SSH- 02LXTSCS	4448-9202	Product Information Ashcroft & Instruments Ashcroft Duragauge Pressure Gauge Bulletin DU-1	N/A	
9203	Pressure Switch	63HG-1 63HG-2 63HG-3	3	363A5542P003	ITT 28150 Industry Dr. Valencia CA 91355	132P4S408- 003	4448-9203	Installation and Operating Instructions Series 132P/232P Adjustable Pressure Switches		
9300	3-Way Ball Valve	N/A	1	361A6239P007	Parker Hannifin 2651 Alabama Highway 21 North Jacksonville, AL 36265	4F- B6XSPKR- V-SSP-LD- 2946	4448-9300	HB Series Ball Valve Installation Instructions		6/98
9301	Pressure Switch	63PG-2	1	363A5542P007	ITT 28150 Industry Dr. Valencia CA 91355	132P4S408- 007	4448-9301	Installation and Operating Instructions Series 132P/232P Adjustable Pressure Switches	N/A	DA
9601	Ball Valve	N/A	2	363A5279P017	Triac Controls 11363 Deerfield Rd. Cincinnati, Ohio 45242	1"- G88SS100- xxx	4448-9601	N/A		
9602	Valve, Manifold 3-Way	N/A	1	354A3280P002	Anderson- Greenwood PO Box 994 Stafford, Texas 77497	M13GVIS-2	4448-9602	N/A		
9603	Gauge, Press Differential 0-25 PSID	FG-3	1	272A6132P042	Mid-West 6500 Dobry Dr. Sterling Heights, MI 48314	120-SC-10- 00	4448-9603	Model 120 Series "Filter Minder" Installation & Operating Instructions Bulletin No IMI 120/99a	120A/00	

FIRST MADE FOR: ML-7A1PEA234**GE DRAWING NUMBER****REV.****378A5570**

-

The information provided in this manual is subject to change without notice, and does not claim to detail all possible operational variations in which the equipment is capable of, nor does this document claim to provide information for every possible situation to be met within the scope of installation, operation and maintenance. In the event further information is required, or particular problems arise which are not sufficiently explained to satisfy the purchasers purposes, the matter should be brought to the attention of the GE Company.

KVAERNER PROCESS SYSTEMS,

Building C 283-291 Treasure Road WELSHPOOL WA 6106 PHONE: (08) 9351-9711 FAX: (08) 9356-1704

[4448-LD-001]

FUEL GAS MODULE EQUIPMENT PARTS LIST**[4448-LD-001]**

GE ORDER DRAWING #: 377A3277										
GE MLI/CC: 0991/7EA										
ITEM #	ITEM DESC	DEVICE #	QTY	GE REF#	COMPONENT SUPPLIER / ADDRESS	COMPONENT SUPPLIER PART #	SKID SUPPLIER PART#	PUB. TITLE	Pub No	Pub Rev
9604	Ball Valve	N/A	5	354A3276P002	Parker Hannifin 2651 Alabama Highway 21 North Jacksonville, AL 36265	6Z-B6LJ-SSP	4448-9604			
9605	Static Pressure Transmitter, Range: 0 - 500PSIG	96FG-2A, 96FG-2B, 96FG-2C, 96FG-4, 96FG-5, 96FG-6	6	353A4330P005	Ametek 1644 Whittier Ave. Costa Mesa CA 92627	PG3000-500-42-12-XX-03-93	4448-9605	3000 Series Pressure Transmitters Manual	N/A	
9606	Valve, 3-Way Ball	N/A	7	361A6239P003	Parker Hannifin 2651 Alabama Highway 21 North Jacksonville, Alabama 36265	4F-B6XSPKR-V-SSP	4448-9606	HB Series Ball Valve Installation Instructions	N/A	
9609	Gauge, Pressure 0 – 400 PSI	FG-3P, FG-3S, FG-3T, FG-2	4	315A2970P108	Ashcroft 250 E. Main St. Stratford CT 06497-5245	45-1379-SSH-02L-XCSTS	4448-9609	Product Information Ashcroft & Instruments Ashcroft Duragauge Pressure Gauge Bulletin DU-1		
9611	Thermocouple, Spring Loaded	FT-GC-1, FT-GC-2, FT-GC-3	3	351A3445P001	Conax Buffalo 2300 Walden Buffalo, NY 14225	K-316SS25-2U-T8EXD (NUSLT3) – 4.00"	4448-9611	Thermocouple Characteristics Table	N/A	
9613	Pressure Transmitter	96FG-1	1	586A2954P007	Rosemount 1 Pandan Crescent Singapore 128461	3051TG3A2 B21AB4E5Q4	4448-9613	N/A		
9614	Pressure Gauge 0-600PSI	FG-1	1	315A2970P109	Ashcroft 250 E. Main St. Stratford Co.	45-1379-SSH-02L-XTSCS		Product Information Ashcroft & Instruments Ashcroft Duragauge Pressure Gauge Bulletin DU-1		

FIRST MADE FOR: ML-7A1PEA234**GE DRAWING NUMBER****REV.****378A5570**

-

The information provided in this manual is subject to change without notice, and does not claim to detail all possible operational variations in which the equipment is capable of, nor does this document claim to provide information for every possible situation to be met within the scope of installation, operation and maintenance. In the event further information is required, or particular problems arise which are not sufficiently explained to satisfy the purchasers purposes, the matter should be brought to the attention of the GE Company.

KVAERNER PROCESS SYSTEMS,

Building C 283-291 Treasure Road WELSHPOOL WA 6106 PHONE: (08) 9351-9711 FAX: (08) 9356-1704

[4448-LD-001]