CT 903047-E-37	DRAWING NUMBER

THIS DRAWING IS CONFIDENTIAL & THE COPYRIGHT OF WORMALD ANSUL (UK) LTD.. THE CONTENTS ARE NOT TO BE USED OR COPIED FOR ANY PURPOSE WHATSOEVER WITHOUT OUR PRIOR WRITTEN CONSENT

DO NOT SCALE ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE OTHERWISE STATED



FRONT VIEW



INTERIOR LAYOUT.



SIDE VIEW

REF.	DESCRIPTION	MAKE	TYPE	LABEL
1	LABEL	WHITE	WHITE-BK-WHITE	JOCKEY PUMP STARTER
2	"	"	"	START
3	"	"	"	STOP
ISOL.	DOOR INTERLOCKED ISOLATOR	MTE	APS1	
FS1.2.3.	FUSE LINK.	G.EC.	NIT 10	JOCKEY PUMP FUSE 10A.
FS.4.5	" "	"	NIT4	400V.AC TO TRANSFORMER SUPPLY
FS6	" "	"	NIT4	110V AC CONTROL SUPPLY FUSE 4
LK1	LINK	"		" " " "
TX1	TRANSFORMER		415/110. 100VA.	TX1
CON1	CONTACTOR	WATFORD	B3000-1	CON1.
OLCC1	THERMAL OVERLOAD RELAY	MTE	UOL1/3-01/153/B	OLCC1
RL1. RL2	RELAY	KEYSWITCH	KM1	RL1 RL2
RES.	RESISTOR BOARD	KAB.		RES1. RES2 RES.3.
TERM	TERMINAL	KLIPPON	SAK4	
PB1	PUSHBUTTON	CRAIG & DERRICOTT	PRCG.	START GREEN
PB2	" STAYPUT STOP		PMRU12 CG.	STOP RED

EXTERIOR FINISH PAINT SHADE BS 381C 631 LIGHT GREY

INTERIOR. ANTI CONDENSATION PAINT WHITE.

HYDRO - ELECTRIC
PETERHEAD GENERATING STATION

CONTRACT NO.	DRAWING NO.	SHEET
2052600/C01	036/1323/7160	0

JOHN BROWN — John Brown Engineering L
Clydebank. Dunbartonshire

J.B.E. ORDER NUMBER :

J.B.E. DRAWING NUMBER: 0998 7403 081 REV

| | | | |