



NOTE(S):
 1. SEE DEVICE SUMMARY FOR CONTROL DEVICE SETTINGS
 2. AD-2: SEE LIQ FUEL/0424
 3. AD-8: SEE ATMG AIR/0425
 5. AD-8: SEE ATMG AIR/0425
 8. BEARING SEALING AIR DIRT SEPARATOR BLOWDOWN VALVE IS TO BE OPEN DURING ALL ABRASIVE AND WATER WASH AND IS TO BE CLOSED AT ALL OTHER TIMES.

ORIFICE DIAMETERS	
INCHES	
A	.031 (.79MM)
B	1.150 (29.21MM)
C	-----
D	5.786 (148.46MM)
E	1.178 (29.92MM)
F	-----
G	1.482 (37.84MM)
H	-----

HYDRO - ELECTRIC		
PETERHEAD GENERATING STATION		
Drawing No.	036/1316/7104	Bht. No. 01
Contract No.	2052600/C01	

FROM ATOMIZING AIR M.L. 0425
 HT. EXCH. CONTINUOUS BLOWDOWN.

I	SYMBOLS, PIPING	277A24
IT.	NOMENCLATURE	IDENT
LIST OF COMPLEMENTARY DOCUMENTS		

WEIGHT IN Kg		SIMILAR TO		B12571.		Drawn		J.McCOLL 20-11-89		SCALE		JOHN BROWN		John Brown Engineering Limited Cydebank, Dunbartonshire G81 1	
REV A		REV B		REV C		Checked		10-1-90		M.L. SECTION					
"IF USED" REFERENCE & NOTES 4 & 7 DELETED		VALVE & PC. CONN. ADDED AT AE-5. BRANCH & NOTE ADDED AT 96CD-1 S.A.L. 29-1-91.		VALVES ADDED TO COMPRESSOR BLEED LINES		Approved				TITLE DIAG. SCHEM. PP-CLG. & SLG. AIR.		DRG. No 0998-0417 B12620.		SHEET No 1 OF 1 SHEETS	
J.McCOLL 9-8-90.						ENGINEERING APPROVAL									
						Mech.									
						Elec.									

JOHN BROWN John Brown Engineering Limited
 Clydebank, Dunbartonshire G81 1