

**TR8 ATTACHMENT REPORT (FOR TCO)**

DEPT BLDGS Job No. 121184841



Scan Code ESHS5417078

Date: August 24, 2018  
Project Address: 550 West 34<sup>th</sup> Street  
Borough: Manhattan  
Work on Floors: 1-51, 51M, ROOF  
DOB Job Number: 121184841  
Design Applicant: Michael Green, RA – KPF Architects  
Owner: Hagen Scutt – Related  
Energy Code Progress Inspection Applicant: Jennifer Sze, RA – Vidaris, Inc.  
Energy Code Progress Inspection Items:  
Protection of exposed foundation insulation (IA1), (IIA1)  
Insulation placement and R values (IA2), (IIA2)  
Fenestration U-value and product rating (IA3), (IIA3)  
Fenestration air leakage (IA4), (IIA4)  
Fenestration areas (IA5), (IIA5)  
Air sealing and insulation- visual (IA6), (IIA6)  
Loading deck weather seals (IIA8)  
Vestibules (IIA9)

This report is an attachment to the TR8 Technical Report signed and sealed on August 24, 2018 by the Energy Code Progress Inspections applicant and submitted for **Temporary Certificate of Occupancy (TCO)**.

Vidaris Inc. performed Energy Code Progress Inspections of items described above.

To the best of my knowledge, completed work at areas inspected was performed in general accordance with:

- the Construction Documents prepared by the Design Applicant
- Approved Tower, Podium and MTA curtain wall shop drawings, storefront shop drawings prepared by New Hudson Facades

**The following work is NOT complete and is EXCLUDED from this TR8 Technical Report:**

1. Weather and air seals at Storefront, ground floor
2. Insulation of terrace concrete slabs: all terraces
3. Insulation of roof concrete slab
4. Loading deck weather seals



Jennifer Sze, RA

8/24/18  
(date)