

February 6, 2015

# ENERGY ANALYSIS FOR MANHATTAN WEST RESIDENTIAL TOWER NEW YORK CITY

Based on the GMP Set dated  
December 15, 2014  
With Revisions

*Submitted by:*  
Viridian Energy & Environmental  
A Vidaris, Inc. Company  
50 Washington Street  
Norwalk, CT 06854  
Adrian Tuluca, RA  
Senior Principal  
Phone: 203-299-1411  
Fax: 203-299-1656  
E-mail: atuluca@vidaris.com

*Prepared for:*  
Brookfield Office Properties  
250 Vesey Street, 15th Floor  
New York, NY 10281  
Megan Brothers  
Phone: 212-417-7297  
E-mail: megan.brothers@brookfield.com

## TABLE OF CONTENTS

REPORT OVERVIEW .....	1
DESIGN BUILDING ENERGY PERFORMANCE .....	1
COMPARISON OF BUILDING DESIGN TO ENERGY CODE .....	3
APPENDIX A - UTILITY RATES .....	19

## REPORT OVERVIEW

The Manhattan West SW Residential building, located in New York City, has approximately 790,000 ft<sup>2</sup> and 63-stories. The building has a mechanical bulkhead and a single-story basement.

The annual energy cost of the building and the savings of its energy efficient measures were estimated with DOE-2.1E energy analysis software.

The building as designed saves 10.2% in regulated energy costs compared to the NYC Energy Conservation Code 2011 baseline. Compliance with the NYC Energy Code is demonstrated by compliance with LL 48/2010 and LL 1/2011, and via the 2010 NYS Energy Construction Conservation Code, Section 506. The building complies with the NYC Energy Code requirements.

The tables below give a summary of results.

### DESIGN BUILDING ENERGY PERFORMANCE

NYC Energy Conservation Code 2011	Total Annual Energy Cost [\$]	Regulated Annual Energy Cost [\$]	Savings Vs. Code Case [\$]	Savings Vs. Code Case [%]	Code Compliant (Y/N)
Code Case: Based on NYCECC 2011	1,818,819	1,255,514			
Design case for Code	1,674,676	1,127,204	128310	10.2%	Y

## Note:

This report is developed for the purpose of calculating the energy performance as per modeling requirements. Actual energy use and cost will be greater, since the modeling rules do not account for many real-life issues, such as quality of construction, equipment functionality, building operation and other factors. Reasons include, but are not limited to the following:

- The code baseline assume perfection, as noted in the bullets below, so the Proposed Design model also must assume perfection:
  - The HVAC equipment is manufactured as per standards. The design of the HVAC systems is such that the each individual piece of equipment performs optimally. The installation is flawless, and the operation optimum.
  - Lighting and lighting controls are perfectly manufactured/installed and function as such.
  - The insulation is installed perfectly. There are no gaps and no rips caused by pipes and wiring. The windows are put in place with perfect caulking.
- Certain real-life effects are not included in the baseline calculations, and therefore are not included in the design calculations either. For instance, the three-dimensional heat loss effect that occurs at the roof parapet
- Occupant behavior is idealized
- Other effects, such as uncertainties in equipment (plug load) operation.

Walls, Above Grade	Walls, Above Grade	A-341 Output Report LV-I
<b>Exterior Wall Construction, Metal Panel</b> <ul style="list-style-type: none"> <li>• Metal Panel</li> <li>• Air Gap</li> <li>• 1-5/8" Mineral Fiber Insulation (R-4.2/Inch), Derated To R-1.02 Per Therm Analysis</li> <li>• 1-3/8" Firestopping (R-3.8/Inch), Derated Per Therm Analysis</li> </ul>	<b>Exterior Wall Construction, Metal Panel</b> <ul style="list-style-type: none"> <li>• Metal Panel</li> <li>• Air Gap</li> <li>• 1-5/8" Mineral Fiber Insulation</li> <li>• 1-3/8" Firestopping</li> </ul>	
<b>Total Wall</b> <ul style="list-style-type: none"> <li>• Overall U-Value = 0.374 Btu/hr-ft<sup>2</sup>-R</li> </ul>	<b>Total Wall</b> <ul style="list-style-type: none"> <li>• Overall U-Value = 0.064 Btu/hr-ft<sup>2</sup>-R</li> </ul>	
Walls, Above Grade	Walls, Above Grade	A-320 Output Report LV-I
<b>Exterior Wall Construction, Solid Wall</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation (R-4.2/Inch), Derated To R-3.85 Per THERM Analysis</li> <li>• Air Gap</li> <li>• 1.8" Concrete Wall</li> </ul>	<b>Exterior Wall Construction, Solid Wall</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation</li> <li>• Air Gap</li> <li>• Concrete Wall</li> </ul>	
<b>Slab Edge Component</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation (R-4.2/Inch), derated To R-4.02 Per THERM Analysis</li> <li>• 1-3/8" Firestopping (R-3.8/Inch) , derated Per THERM Analysis</li> <li>• Concrete Slab</li> </ul>	<b>Slab Edge Component</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation</li> <li>• 1-3/8" Firestopping</li> <li>• Concrete Slab</li> </ul>	
<b>Total Wall</b> <ul style="list-style-type: none"> <li>• Overall U-Value = 0.159 Btu/hr-ft<sup>2</sup>-R</li> </ul>	<b>Total Wall (mass)</b> <ul style="list-style-type: none"> <li>• Overall U-Value = 0.090 Btu/hr-ft<sup>2</sup>-R</li> </ul>	
<b>Vertical Glazing</b> <ul style="list-style-type: none"> <li>53.4% vertical glazing</li> </ul>	<b>Vertical Glazing</b> <ul style="list-style-type: none"> <li>40% vertical glazing</li> </ul>	A-200 Output Report LV-D

## COMPARISON OF BUILDING DESIGN TO ENERGY CODE

The following table shows the comparison of the Proposed Design Case and the NYC Energy Code Case:

Design case	NYC Energy Code	Design Source
<b>Walls, Above Grade</b> <ul style="list-style-type: none"> <li>• <b>Exterior Wall Construction, Spandrel Panel</b></li> <li>• Spandrel Wall Component</li> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation (R-4.2/Inch), Derated To R-3.25 Per Therm Analysis</li> <li>• Air Gap</li> <li>• 4" Foil Faced Batt Insulation (R-13 Batts), Derated To R-1.75 Per Therm Analysis</li> <li>• Backing Board</li> <li>• Gypsum Board</li> </ul>	<b>Walls, Above Grade</b> <ul style="list-style-type: none"> <li>• <b>Exterior Wall Construction, Spandrel Panel</b></li> <li>• Spandrel Wall Component</li> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• 5" Mineral Fiber Insulation</li> <li>• Air Gap</li> <li>• 4" Foil Faced Batt Insulation</li> <li>• Backing Board</li> <li>• Gypsum Board</li> </ul>	A-314.00 Output Report LV-I
<b>Slab Edge Component</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• Air Gap</li> <li>• 1-1/2" Mineral Fiber Insulation (R-4.2/Inch), Derated To R-1.42 Per Therm Analysis</li> <li>• 1-3/8" Firestopping (R-3.8/Inch) , Derated Per Therm Analysis</li> <li>• Concrete Slab</li> </ul>	<b>Slab Edge Component</b> <ul style="list-style-type: none"> <li>• Insulated Glass Assembly (W/Mullions)</li> <li>• Air Gap</li> <li>• 1-1/2" Mineral Fiber Insulation</li> <li>• 1-3/8" Firestopping</li> <li>• Concrete Slab</li> </ul>	
<b>Total Wall</b> <ul style="list-style-type: none"> <li>• Overall U-Value = 0.178 Btu/hr-ft<sup>2</sup>-R</li> </ul>	<b>Total Wall</b> <ul style="list-style-type: none"> <li>Overall U-Value = 0.064 Btu/hr-ft<sup>2</sup>-R</li> </ul>	

<ul style="list-style-type: none"> <li>Underground wall construction</li> <li>1.5" Polystyrene Insulation (R-7.5)</li> <li>14" Concrete</li> <li>C-0.119 (wall only; without soil)</li> <li>per ASHRAE 90.1-2007 Table A4.2</li> <li>U = 0.110 including interior air-film</li> </ul>	<ul style="list-style-type: none"> <li>Underground wall construction</li> <li>14" Concrete</li> <li>C-1.140 (wall only; without soil)</li> <li>U = 0.642 including interior air-film</li> </ul>	A-306 LV-I output report
<ul style="list-style-type: none"> <li>Slab-on-grade construction</li> <li>Soil</li> <li>Gravel</li> <li>Concrete slab</li> <li>Unheated</li> <li>F-factor = F-0.730</li> </ul>	<ul style="list-style-type: none"> <li>Slab-on-grade construction</li> <li>Soil</li> <li>Gravel</li> <li>Concrete slab</li> <li>Unheated</li> <li>F-factor = F-0.730</li> </ul>	A-310 No output verification available
<b>Lighting</b> <b>Lighting Power Density</b> Apartments Owner-provided Tenant-provided 0.61 W/ft <sup>2</sup> 0.7 W/ft <sup>2</sup> Amenity Basketball court Cafeteria Corridor Electrical EMR Lobby Locker Lounge Mail room Mechanical Office Retail Stairwells Storage General BOH 0.4 W/ft <sup>2</sup>	<b>Lighting</b> <b>Lighting Power Density</b> Whole Building, Excluding Retail 0.7 W/ft <sup>2</sup> Retail 1.5 W/ft <sup>2</sup>	E-200.00, E-202.00, E-204.00, E-206.00, E-208.00 thru E-217.00, E-402.00 LV-B Output report

1 43% of the apartment area has owner-provided lighting (i.e. kitchens, baths, and hallways). The rest of the apartment has tenant-provided lighting which is the same as the Baseline.

<ul style="list-style-type: none"> <li>Hybrid Window Wall (53.1%)</li> <li>Solar heat gain coefficient (SHGC) = 0.23</li> <li>Visible Light Transmittance = 0.31</li> <li>U-factor (assembly) = U-0.49</li> </ul>	<ul style="list-style-type: none"> <li>Metal glazing, all other (39.8%)</li> <li>Solar heat gain coefficient (SHGC) = 0.40</li> <li>U-factor (assembly) = U-0.55</li> </ul>	
<ul style="list-style-type: none"> <li>Storefront Window (0.3%)</li> <li>Solar heat gain coefficient (SHGC) = 0.82</li> <li>Visible Light Transmittance = 0.76</li> <li>U-factor (assembly) = U-1.25</li> </ul>	<ul style="list-style-type: none"> <li>Metal glazing, storefront (0.2%)</li> <li>Solar heat gain coefficient (SHGC) = 0.40</li> <li>U-factor (assembly) = U-0.50</li> </ul>	
<b>Roofs</b> <b>Terrace Roof Construction</b> 2" Pavers R = 0.3, degraded 50% Air Space R=0.82 Filter Fabric (R-20) 4" Extruded Polystyrene Insulation (Continuous) Drainage Mat Reinforced Cold Fluid Applied Membrane 2" Lightweight Concrete Topping Slab Structural Concrete Deck U-factor = U-0.044 <b>Roofs</b> <b>Mechanical Roof Construction</b> Gravel Ballast Filter Fabric (R-20) 4" Extruded Polystyrene Insulation (Continuous) Drainage Mat Reinforced Cold Fluid Applied Membrane 2" Lightweight Concrete Topping Slab Structural Concrete Deck U-factor = U-0.046	<b>Roofs</b> <b>Insulation entirely above deck</b> 2" Pavers Air Space Filter Fabric (R-20) 4" Extruded Polystyrene Insulation (Continuous) Drainage Mat Reinforced Cold Fluid Applied Membrane Topping Slab Structural Concrete Deck U-factor = U-0.048 <b>Roofs</b> <b>Insulation entirely above deck</b> Gravel Ballast Filter Fabric (R-20) 4" Extruded Polystyrene Insulation (Continuous) Drainage Mat Reinforced Cold Fluid Applied Membrane Topping Slab Structural Concrete Deck U-factor = U-0.048	A-320 through A-325 Output Report LV-I

<p>Other Multifamily Public &amp; Common Areas: 1.6 annual kWh/ ft²</p> <p>Office: 4.9 annual kWh/ ft²</p>			
<p><b>Heating Schedule</b></p> <p>Heating temperature is set for 72° F during the hours of operation with a 65° F setback during unoccupied hours between January 1 thru May 15 and October 1 thru December 31.</p>	<p><b>Heating Schedule</b></p> <p>Same as design</p>	Assumed- Unregulated	No output report
<p><b>Cooling Schedule</b></p> <p>Cooling temperature is set at 75° F for corridors.</p> <p>Cooling in apartments is set at 75F during occupancy hours, with an 80° F setback during unoccupied hours from April 15 thru October 31.</p> <p>Cooling is available in common areas all year.</p>	<p><b>Cooling Schedule</b></p> <p>Same as design</p>	Assumed- Unregulated	No output report
<p><b>HVAC – Low-rise corridors (AC-4-1)</b></p> <ul style="list-style-type: none"> <li>• Packaged DX unit with Dry Cooler</li> <li>• Cooling EER = 14.2</li> <li>• Total cooling capacity = 848 MBH</li> <li>• Steam heating coils (boiler thermal efficiency = 82%)</li> <li>• 13,000 cfm outside air</li> <li>• Supply CFM = 13,000</li> <li>• Supply BHP = 11.2 HP</li> <li>• Return BHP = 11.2 HP</li> <li>• Exhaust air heat recovery via enthalpy heat recovery wheel. Recovery efficiency = 85.4%</li> </ul>	<p><b>HVAC – Low-rise corridors (AC-4-1)</b></p> <ul style="list-style-type: none"> <li>• System #4; Packaged VAV with reheat</li> <li>• Cooling EER=9.5 (&gt;760 MBH)</li> <li>• Cooling IPLV = 9.3</li> <li>• Total cooling capacity = 1062 MBH</li> <li>• Hot water heating coils (boiler combustion efficiency = 82%)</li> <li>• 13,000 cfm outside air</li> <li>• Supply CFM = 13,000</li> <li>• Supply BHP = 11.2 HP</li> <li>• Return BHP = 11.2 HP</li> <li>• Exhaust air heat recovery with recovery efficiency = 50%</li> </ul>	M-401	SV-A output report Note- boiler flue heat recovery is not modeled for compliance

Occupancy sensors  Occupancy sensors for lighting control in stairwells, corridors, office, storage, lounge, gym, and cafe. <ul style="list-style-type: none"><li>In the BOH corridors, offices, storage rooms and stairwells the lighting usage is reduced by 10%.</li></ul>	Occupancy sensors  Vacancy sensors in office	E-200.00, E-202.00, E-204.00, E-206.00, E-208.00 thru E217.00, E-402.00																											
Exterior Lighting Tradable Lighting <table><tr><td>Category</td><td>Area</td><td>Wattage</td></tr><tr><td>Plaza</td><td>6430</td><td>592</td></tr><tr><td>Other Door</td><td>9</td><td>120</td></tr><tr><td>Total</td><td></td><td>712 W</td></tr></table>	Category	Area	Wattage	Plaza	6430	592	Other Door	9	120	Total		712 W	Exterior Lighting Lighting Zone 2 Tradable Lighting <table><tr><td>Category</td><td>Area</td><td>Wattage</td></tr><tr><td>Plaza</td><td>6430</td><td>900.2</td></tr><tr><td>Other Door</td><td>9</td><td>180</td></tr><tr><td>Base Site Allowance</td><td></td><td>600</td></tr><tr><td>Total</td><td></td><td>1680.2 W</td></tr></table>	Category	Area	Wattage	Plaza	6430	900.2	Other Door	9	180	Base Site Allowance		600	Total		1680.2 W	E-217, E219 Note- Temporary parking lighting on E-202 is not included
Category	Area	Wattage																											
Plaza	6430	592																											
Other Door	9	120																											
Total		712 W																											
Category	Area	Wattage																											
Plaza	6430	900.2																											
Other Door	9	180																											
Base Site Allowance		600																											
Total		1680.2 W																											
Energy Star appliances in apartments (based on MFHR guidelines)  Energy Use Appliances kWh/Year Refrigerator 423 Dishwasher 164 Clothes washer 57 Clothes dryer 535  An additional plug load of 1.05 annual kWh/ft² for miscellaneous equipment in apartments  Gas cooking at 4.5 Million-Btu annually per apartment.	Energy Star appliances in apartments (based on MFHR guidelines)  Same as Design	Assumed- Unregulated LV-B output report																											
Plug loads (other than apartments) based on MFHR guidelines  Corridors, restrooms, stairs, and support areas: 0.7 annual kWh/ ft²	Plug loads (other than apartments) based on MFHR guidelines  Same as design	Assumed- Unregulated LV-B output report																											



<ul style="list-style-type: none"> <li>Hot water heating coils (boiler thermal efficiency = 82%)</li> <li>No airside economizer controls</li> <li>OA cfm = 1,700</li> <li>Supply CFM = 10,000</li> <li>Supply fan BHP = 7.72 HP</li> <li>Return fan BHP = 4.01 HP</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm per design documents</li> </ul>	<ul style="list-style-type: none"> <li>Hot water heating coils (boiler combustion efficiency = 82%)</li> <li>Enthalpy controlled airside economizer</li> <li>OA cfm = 1,700</li> <li>Supply CFM = 10,539</li> <li>Fan BHP = 8.13</li> <li>Return Fan BHP = 4.23</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	
<b>HVAC – Lounge (AC-63-2, AGC-64-2, RF-63-1)</b> <ul style="list-style-type: none"> <li>Split Air-cooled packaged DX unit</li> <li>Cooling capacity = 520 MBH</li> <li>Cooling EER=9.8</li> <li>Heating from 80% efficient furnace</li> <li>Heating capacity = 480 MBH</li> <li>No airside economizer controls</li> <li>OA cfm = 3,000</li> <li>Supply CFM = 14,000</li> <li>Supply fan BHP = 16 HP</li> <li>Return fan BHP = 4.5 HP</li> <li>Fan bhp/cfm per design documents</li> </ul>	<b>HVAC – Lounge (AC-63-2)</b> <ul style="list-style-type: none"> <li>System #11: Packaged rooftop AC</li> <li>Cooling capacity = 757 MBH</li> <li>Cooling EER=9.8 (240-760 MBH)</li> <li>Cooling IPLV = 9.5</li> <li>Heating from 80% efficient furnace</li> <li>Heating capacity = 588 MBH</li> <li>Airside economizer controls</li> <li>OA cfm = 3,000</li> <li>Supply CFM = 21,835</li> <li>Supply fan BHP = 24.9 HP</li> <li>Return fan BHP = 7.0 HP</li> <li>Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	M-401, M-402
<b>HVAC – Back-Of-House (AC-3-1, RF-3-1)</b> <ul style="list-style-type: none"> <li>Packaged DX unit with Dry Cooler</li> <li>Cooling capacity = 535 MBH</li> <li>Cooling EER=13.6</li> <li>Hot water heating coils (boiler thermal efficiency = 82%)</li> <li>No airside economizer controls</li> </ul>	<b>HVAC – Back-Of-House (AC-3-1)</b> <ul style="list-style-type: none"> <li>System #4: Packaged VAV w/ reheat</li> <li>Cooling capacity = 815 MBH</li> <li>Cooling EER=9.5 (&gt;760 MBH)</li> <li>Cooling IPLV = 9.2</li> <li>Hot water heating coils (boiler combustion efficiency = 82%)</li> <li>Enthalpy controlled airside economizer</li> <li>OA cfm = 2,800</li> </ul>	M-401, M-402

<ul style="list-style-type: none"> <li>Hot water heating coils (boiler thermal efficiency = 82%)</li> <li>Additional air distribution via fan powered boxes</li> <li>No economizer controls</li> <li>OA cfm = 6,500</li> <li>Supply CFM = 15,000</li> <li>Supply fan BHP = 13.6 HP</li> <li>Return fan BHP = 5.39 HP</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm per design documents</li> </ul>	<ul style="list-style-type: none"> <li>Hot water heating coils (boiler combustion efficiency = 82%)</li> <li>Enthalpy controlled airside economizer</li> <li>OA cfm = 6,500</li> <li>Supply CFM = 15,086</li> <li>Supply fan BHP = 13.6 HP</li> <li>Return fan BHP = 5.39 HP</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	
<b>HVAC – Basketball court (AC-4-2, RF-3-4)</b> <ul style="list-style-type: none"> <li>Packaged DX unit with Dry Cooler</li> <li>Cooling capacity = 461 MBH</li> <li>Cooling EER = 14.4</li> <li>Hot water heating coils (boiler thermal efficiency = 82%)</li> <li>Variable volume fan</li> <li>No airside economizer controls</li> <li>OA cfm = 2,100</li> <li>Supply CFM = 11,000</li> <li>Supply Fan BHP = 8.94 HP</li> <li>Return Fan BHP = 4.25 HP</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm per design documents</li> </ul>	<b>HVAC – Basketball court (AC-4-2)</b> <ul style="list-style-type: none"> <li>System #11: Packaged rooftop AC</li> <li>Total cooling capacity = 359 MBH</li> <li>Cooling EER=9.8 (240-760 MBH)</li> <li>Cooling IPLV = 9.5</li> <li>Heating from 80% efficient furnace coils</li> <li>Heating capacity = 300 MBH</li> <li>Constant volume fan</li> <li>Enthalpy controlled airside economizer</li> <li>OA cfm = 2,100</li> <li>Supply CFM = 8,023</li> <li>Supply Fan BHP = 6.52 HP</li> <li>Return Fan BHP = 3.1 BHP</li> <li>MERV 13 filters</li> <li>Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	M-401
<b>HVAC – Amenity (AC-4-3, RF-3-5)</b> <ul style="list-style-type: none"> <li>Packaged DX unit with Dry Cooler</li> <li>Cooling capacity = 461 MBH</li> <li>Cooling EER=14.4</li> </ul>	<b>HVAC – Amenity (AC-4-3)</b> <ul style="list-style-type: none"> <li>System #4: Packaged VAV w/ reheat</li> <li>Cooling capacity = 467 MBH</li> <li>Cooling EER=9.8 (240-760 MBH)</li> <li>Cooling IPLV = 9.5</li> </ul>	M-401

<p><b>HVAC – 36<sup>th</sup> floor support spaces (AC-36-1 thru 4 (AC-36-2 &amp; 4 standby))</b></p> <ul style="list-style-type: none"> <li>• Packaged water cooled DX unit with Dry Cooler</li> <li>• Total cooling capacity = 137 MBH (active units only)</li> <li>• Average cooling EER=12.69</li> <li>• No heating</li> <li>• Constant volume</li> <li>• Water-side economizer when CW temp is below 44F</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 5,850</li> <li>• Fan HP = 4.0 HP</li> <li>• Fan hp/cfm per design documents</li> </ul>	<p><b>HVAC – 36<sup>th</sup> floor support spaces (AC-36-1 thru 4)</b></p> <ul style="list-style-type: none"> <li>• System #11: Packaged rooftop AC</li> <li>• Total Cooling capacity = 17.8 MBH (2 units)</li> <li>• Cooling SEER=13.0 (&lt;65 MBH)</li> <li>• Heating from 80% efficient furnace</li> <li>• Heating capacity = 26.8 MBH</li> <li>• Constant volume</li> <li>• Constant volume</li> <li>• No economizer control</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 1,358</li> <li>• Fan HP = 0.9 HP</li> <li>• Fan hp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	M-401
<p><b>HVAC – EMR (AC-65-1 thru 4, ACC-64-1 thru 4, ACC-64-2&amp;4 standby)</b></p> <ul style="list-style-type: none"> <li>• Split air-cooled Packaged DX unit</li> <li>• Total cooling capacity = 144.3 MBH</li> <li>• Average cooling EER=11.08</li> <li>• Electric heating</li> <li>• Constant volume</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 5850</li> <li>• Fan HP = 7 HP</li> <li>• Fan hp/cfm per design documents</li> </ul>	<p><b>HVAC – EMR (AC-65-1 thru 4)</b></p> <ul style="list-style-type: none"> <li>• System #9: Packaged rooftop HP</li> <li>• Total Cooling capacity = 121 MBH (2 units)</li> <li>• Cooling SEER = 13 (&lt;65 MBH)</li> <li>• Heating capacity = 260 MBH</li> <li>• Heating HSPF = 7.7 (&lt;65 MBH cooling cap)</li> <li>• Constant volume</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 8863</li> <li>• Fan BHP =10.6 HP</li> <li>• Fan hp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	M-401
<p><b>HVAC-Security (AC-1-1)</b></p> <ul style="list-style-type: none"> <li>• Packaged water cooled DX unit with Dry Cooler</li> <li>• Cooling capacity = 57.3 MBH</li> <li>• Average cooling SEER = 13</li> </ul>	<p><b>HVAC-Security (AC-1-1)</b></p> <ul style="list-style-type: none"> <li>• System #11: Packaged rooftop AC</li> <li>• Cooling capacity = 25 MBH</li> <li>• Cooling SEER=13.0 (&lt;65 MBH)</li> <li>• Heating from 80% efficient furnace</li> </ul>	M-401

<ul style="list-style-type: none"> <li>• OA cfm = 2,800</li> <li>• Supply CFM = 14,000</li> <li>• Supply fan BHP = 13.7 HP</li> <li>• Return fan BHP = 6.52 HP</li> <li>• MERV 13 filter</li> <li>• Fan bhp/cfm per design documents</li> </ul>	<ul style="list-style-type: none"> <li>• Supply CFM = 22,167</li> <li>• Supply fan BHP = 21.7 HP</li> <li>• Return fan BHP = 10.3 HP</li> <li>• MERV 13 filter</li> <li>• Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	
<p><b>HVAC – Retail</b></p> <ul style="list-style-type: none"> <li>• Air-cooled packaged DX unit</li> <li>• Cooling capacity = 94 MBH</li> <li>• Cooling EER=11.0 (65-135 MBH)</li> <li>• Heating from 80% efficient furnace</li> <li>• Heating capacity = 151 MBH</li> <li>• Constant volume</li> <li>• Enthalpy controlled airside economizer</li> <li>• OA cfm = 562</li> <li>• Supply CFM = 2,808</li> <li>• Fan BHP = 3.8 HP</li> <li>• Fan bhp/cfm per NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	<p><b>HVAC – Retail</b></p> <ul style="list-style-type: none"> <li>• System #11: Packaged rooftop AC</li> <li>• Cooling capacity = 94 MBH</li> <li>• Cooling EER=11.0 (65-135 MBH)</li> <li>• Heating from 80% efficient furnace</li> <li>• Heating capacity = 151 MBH</li> <li>• Constant volume</li> <li>• Enthalpy controlled airside economizer</li> <li>• OA cfm = 562</li> <li>• Supply CFM = 2,808</li> <li>• Fan BHP = 3.8 HP</li> <li>• Fan bhp/cfm per NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	Assumed, tenant fit-out
<p><b>HVAC – Cellar support spaces (AC-B1-1 thru 5, EF-B-2, EF-B-3, EF-3-1)</b></p> <ul style="list-style-type: none"> <li>• Packaged water cooled DX unit with Dry Cooler</li> <li>• Total cooling capacity = 535 MBH</li> <li>• Average cooling EER=13.67</li> <li>• No heating</li> <li>• Constant volume</li> <li>• Water-side economizer when CW temp is below 44F</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 22,815</li> <li>• Supply fan BHP = 18.2 HP</li> <li>• Return fan BHP = 1.75 HP</li> <li>• Fan bhp/cfm per design documents</li> </ul>	<p><b>HVAC – Cellar support spaces (AC-B1-1 thru 5)</b></p> <ul style="list-style-type: none"> <li>• System #11: Packaged rooftop AC</li> <li>• Total Cooling capacity = 210 MBH (5 units)</li> <li>• Cooling SEER=13.0 (&lt;65 MBH)</li> <li>• Heating from 80% efficient furnace</li> <li>• Heating capacity = 415 MBH</li> <li>• Constant volume</li> <li>• No economizer control</li> <li>• OA cfm = 0 (total)</li> <li>• Supply CFM = 21,323 (total)</li> <li>• Supply fan BHP = 17.0 HP</li> <li>• Return bhp = 1.6 HP kW</li> <li>• Fan bhp/cfm equal to design case, within the NYSECCC 2010, Section 503.2.10.1 requirements</li> </ul>	M-401



<ul style="list-style-type: none"> <li>Hot water pumps = 37.8 W/gpm</li> <li>Variable speed drives with minimum turndown ratio of 50%</li> </ul>	<ul style="list-style-type: none"> <li>Hot water pumps = 37.8 W/gpm</li> <li>Variable speed drives with minimum turndown ratio of 50%</li> </ul>	
Steam Condensate Pumps	Steam Condensate Pumps	M-402
<ul style="list-style-type: none"> <li>23 W/gpm</li> <li>400 gpm</li> <li>Variable speed drives with minimum turndown ratio of 50%</li> </ul>	N/A	
Dry Coolers	Cooling Towers	M-402
<ul style="list-style-type: none"> <li>Three Dry Coolers 100 Tons each</li> <li>One Dry Cooler of 20 Tons</li> <li>Fan Power: 15 hp for each 100-Ton unit; 3 hp for the 20-Ton unit</li> <li>Pump: 12.7 bhp for each 100-Ton unit; 5.9 bhp for the 20-Ton unit</li> </ul>	N/A	Note- Dry-cooler energy is accounted for in the efficiency of the air conditioning units. Please see calculations following table.
Domestic Hot Water	Domestic Hot Water	P-401
<ul style="list-style-type: none"> <li>Condensing boilers with 97% efficiency, modulating flame burner.</li> <li>Heat recovered from the low pressure steam HW boiler flue is used to pre-heat DHW.</li> </ul>	<ul style="list-style-type: none"> <li>Gas fired hot water heater with 80% efficiency, on/off control</li> </ul>	Note- boiler flue heat recovery is not modeled for compliance

<ul style="list-style-type: none"> <li>Heating via hot water baseboards</li> <li>Water-side economizer when CW temp is below 44F</li> <li>Constant volume</li> <li>OA cfm = 0 (total)</li> <li>Supply CFM = 2,500</li> <li>Supply fan HP = 2.0 HP</li> <li>Fan hp/cfm per design documents</li> </ul>	<ul style="list-style-type: none"> <li>Heating capacity = 94 MBH</li> <li>No economizer control</li> <li>Constant volume</li> <li>OA cfm = 0 (total)</li> <li>Supply CFM = 3,178</li> <li>Supply fan BHP = 2.5 HP</li> <li>Fan bhp/cfm equal to design case, within the NYSECC 2010, Section 503.2.10.1 requirements</li> </ul>	
HVAC- Saily Port (AC-S-1thru3, SF-1-1, EF-1-2) <ul style="list-style-type: none"> <li>Split air-cooled Packaged DX unit</li> <li>Average cooling EER=40.7</li> <li>Electric heating</li> <li>Constant volume</li> <li>OA cfm = 500 (total)</li> <li>Supply CFM = 3730</li> <li>Supply Fan BHP = 1.53 HP</li> <li>Exhaust fan BHP = 1.33</li> <li>Fan hp/cfm per design documents</li> </ul>	HVAC- Saily Port (AC-S-1thru3, SF-1-1, EF-1-2) <ul style="list-style-type: none"> <li>System #9: Packaged rooftop HP</li> <li>Cooling capacity = 42.5 MBH</li> <li>Cooling SEER = 13 (&lt;65 MBH)</li> <li>Heating HSPF = 7.7 (&lt;65 MBH)</li> <li>Heating capacity = 45 MBH</li> <li>Constant volume</li> <li>OA cfm = 500 (total)</li> <li>Supply CFM = 5741</li> <li>Supply fan BHP = 2.0 kW</li> <li>Fan bhp/cfm equal to design case, within the NYSECC 2010, Section 503.2.10.1 requirements</li> </ul>	M-402
Heating Plant <p>Heating is provided by two 8,368 MBH and one 4,184 MBH low pressure steam boilers. The boiler thermal efficiency is 82%. The boilers have modulating flame burner.</p> <p>There is heat recovery from the boiler flue for the lower residential corridors outside air supply and DHW heating. (EC-1, EC-2, EC-3)</p> <p>Hot Water Pumps (HWP-4-1/2, GWP-4-4/5, HWP-63-1/2, one stand-by for each type, 3 active)</p> <ul style="list-style-type: none"> <li>Total flow = 265 gpm</li> </ul>	Heating Plant <p>Heating is provided by two 9,670 MBH hot water boilers. The boiler combustion efficiency is 82%. The boilers have ON-OFF flame burner.</p>	M-401
		PS-H Output report * Proposed modeled as (3) 6973 MBH boilers. DOE2.1E does not allow different boiler sizes. Boiler flue heat recovery is not modeled for compliance
	Hot Water Pumps	M-402
<ul style="list-style-type: none"> <li>Total flow = 772 gpm</li> </ul>		

Proposed Case Modeled Cooling Efficiency with Dry Cooler Adjustments

DOE 2.1 System	Proposed Unit	Cooling Capacity (MBH)	EER	EER w/o Fans per ASHRAE 90.1-2010 Addendum bl	Cooling Eff. w/o fans, kW/ton	Dry Cooler serving Unit	Dry Cooler Adjustment (kW/ton)	Total Efficiency (kW/ton)	Modeled EIR
AC-1-1	AC-1-1	57.3	12.3	14.37	0.8349	AC-DC-1thru3	0.231	1.0659	0.3031
AC-3-4	AC-3-4	825	14	19.24	0.6239	AC-DC-1thru3	0.231	0.8549	0.2431
AC-36-1-4	AC-36-1, 2	79.5	11	12.92	0.9288	AC-DC-64-1	0.369	1.2978	
AC-36-1-4	AC-36-3, 4	57.3	12.3	14.37	0.8349	AC-DC-64-1	0.369	1.2039	
AC-36-1-4, All Units								1.2585	0.3578
AC-4-2	AC-4-2	461	14.4	18.38	0.6528	AC-DC-1thru3	0.231	0.8838	0.2513
AC-4-3-AMENITY-S	AC-4-3	450	14.4	18.34	0.6543	AC-DC-1thru3	0.231	0.8853	0.2517
AC-63-2	AC-63-2	520	9.8	12.67	0.9475			0.9475	0.2694
AC-81-1-5	AC-81-1, 2	161.6	11.1	13.28	0.9035	AC-DC-1thru3	0.231	1.1345	
AC-81-1-5	AC-81-3, 4	22.9	12.4	14.38	0.8347	AC-DC-1thru3	0.231	1.0657	
AC-81-1-5	AC-81-5	31.9	13.4	15.57	0.7708	AC-DC-1thru3	0.231	1.0018	
AC-81-1-5, All Units								1.1077	0.3150
BOH-SYS	AC-3-1	535	13.6	17.63	0.6806	AC-DC-1thru3	0.231	0.9116	0.2592
CORR-SYS	AC-4-1	848	14.2	19.60	0.6123	AC-DC-1thru3	0.231	0.8433	0.2398
EMR-SYS	AC-65-1, 2	83.9	11.2	13.17	0.9113			0.9113	
EMR-SYS	AC-65-3, 4	60.4	11.2	13.10	0.9162			0.9162	
EMR-SYS, All Units								0.9134	0.2597
LOBBY-SYS	AC-3-2	432	14.6	18.52	0.6478	AC-DC-1thru3	0.231	0.8788	0.2499
RF-CORR-SYS	AC-63-1	693	10.1	13.52	0.8876			0.8876	0.2524
SALLY-SYS	AC-5-1	20.9	9.0	10.43	1.1506			1.1506	
SALLY-SYS	AC-5-2, 3	27.4	11.3	13.11	0.9150			0.9150	
SALLY-SYS, All Units								1.0169	0.2892

Dry Cooler Efficiency Modifications for Energy Model

	Dry Cooler Set 1 AC-DC-1thru3	Dry Cooler Set 2 AC-DC-64-1
Cooling capacity Served (MBH)	3824.7	136.8
Cooling capacity Served (tons)	300	20
Dry Cooler Pump Power (BHP)	38.1	5.9
Pump Efficiency	93%	92%
Dry Cooler Pump Power (kW)	30.6	4.8
Dry Cooler Fan Power (HP)	1.5	1.5
# Dry Cooler Fans	15	2
Total Dry Cooler Fan Power (HP)	45	3
Fan motor efficiency	86.5%	86.5%
Total Fan Power (kW)	38.8	2.6
Total Dry Cooler Power (kW)	69.4	7.4
Dry Cooler kW/ton	0.231	0.369

March	\$1,344	\$1,159	\$1,025
April	\$1,197	\$1,013	\$0,878
May	\$1,142	\$0,958	\$0,824
June	\$1,416	\$1,232	\$1,097
July	\$1,444	\$1,259	\$1,125
August	\$1,443	\$1,259	\$1,124
September	\$1,413	\$1,228	\$1,094
October	\$1,351	\$1,167	\$1,032
November	\$1,363	\$1,179	\$1,044
December	\$1,396	\$1,212	\$1,077

Note: Cooking gas rates will be different but have not been modeled separately at this stage in the design. The results will not be significantly different since we are not taking any credit for cooking gas use in the design.

## APPENDIX A - UTILITY RATES

The energy model uses the following utility rates to calculate the building's energy cost.

### 1.1. Electricity

ConEdison PSC-9, SC-8, Rate II (Large Multiple Dwelling - Redistribution), low tension

NY Sales Tax: 8.875 %

Time Period	Demand Charge		Energy Charge	
	M-F, 8am-6 pm per kW	M-F, 8am-10pm per kW	All hours per kWh	M-F 8am-10pm per kWh Other hours per kWh
January	\$26.60	\$19.56	\$9.53	\$0.1150 \$0.0984
February	\$26.60	\$19.56	\$9.53	\$0.0979 \$0.0908
March	\$26.60	\$19.56	\$9.53	\$0.1073 \$0.0963
April	\$26.60	\$19.56	\$9.53	\$0.1051 \$0.0925
May	\$35.15	\$28.11	\$18.09	\$0.1122 \$0.0895
June	\$60.80	\$41.65	\$26.54	\$0.1188 \$0.0853
July	\$60.80	\$41.65	\$26.54	\$0.1395 \$0.1009
August	\$60.80	\$41.65	\$26.54	\$0.0843 \$0.0615
September	\$35.76	\$28.73	\$18.70	\$0.1108 \$0.0935
October	\$26.60	\$19.56	\$9.53	\$0.0764 \$0.0605
November	\$26.60	\$19.56	\$9.53	\$0.1048 \$0.0926
December	\$26.60	\$19.56	\$9.53	\$0.0941 \$0.0841

### 1.2. Gas

ConEdison PSC-9 Gas, SC-3 (Residential and Religious - Heating Firm Sales)

Monthly customer charge: \$18.60  
NY Sales Tax: 8.875 %

Time Period	Energy Charge	
	First 90 therms per therm	Next 2,910 therms per therm over 3000 therms per therm
January	\$1,369	\$1,185
February	\$1,325	\$1,141
		\$1,006

