



AI1: Additional Information Must be typewritten.

☒ Orient and affix BIS job number label here ☒

Page number 1 of 1 BIS Document No. _____

1 Location and Job Information Required for all applications.

House No(s) 401 Street Name 9th Avenue

Borough Manhattan

Block 00729

Lot 00060

BIN 1800650

CB No. 104

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

| Action | Original/New/ Omit Page ID | Superseding Page ID | Action | Original/New/ Omit Page ID | Superseding Page ID | Action | Original/New/ Omit Page ID | Superseding Page ID | Action | Original/New/ Omit Page ID | Superseding Page ID |
|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

additional comments:

Please clarify the changes to the model. Provide explanation in AI1 for the following model changes, submit revised drawings to match changes as required to match energy model:

- Lighting W/SF and operating schedules have not changed since the last submission. The PSE report shows that energy consumption for "AREA LIGHTS" have decreased
- Plug load Equipment W/SF and operating schedules have not changed since the last submission. The PSE report shows significant decrease in energy consumption for "MISC EQUIPMT".

RESPONSE:

- There are two plants in this project. Therefore there are two PS-E reports for each run. If we add the "AREA LIGHTS" for the two PS-E reports, we get the same values in the new submission vs. the last submission.
- We reduced the plug loads as follows to be in line with the size of HVAC equipment in the proposed design:

Electrical rooms from 5 W/sf to 2 W/sf

IT rooms from 10 W/sf to 5 W/sf

The plug loads are the same in the Design and the Code Baseline.



Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

Adrian Tuluca

Signature

P.E. / R.A. Seal (apply seal, then sign and date over seal)



Date