

---

**TR-1: Report**No. 1520

---

Date: May 05, 2016

**RE: Hudson Yards Tower C: TR-1 for Storefront and Cable-Wall Enclosures**

---

This TR-1 dated 05/05/2016 has been requested by The Related Group and Tutor Perini Building Corp for the exterior cable wall and storefront wall systems to obtain a Temporary Certificate of Occupancy.

As of May 2016, substantial completion of exterior wall systems within the following scope has been achieved: East and West storefronts (Levels 1-5M); South, East, and West lobby cable walls (Levels 1-5M); and South Atrium cable wall (Levels 6-21). Minor work remains at the East Storefront on Level 1. Punch list remedial work remains ongoing (refer to attached punch list). The South Marketplace Storefront Wall on Level 1 has yet to be installed and will be inspected upon completion. All other systems within inspection scope have been inspected in accordance with Section 1704.10 of the 2008 New York City Building Code and are substantially in accordance with exception to items noted on attached "Special Inspections Outstanding Items, Issue No. 1520-TR-1 Report" dated May 05, 2016.

The inspector assumes no responsibility for the design and implementation of safe egress paths out of the building as may be required for the Temporary Certificate of Occupancy.

Heintges & Associates has been contracted by The Related Group as the Inspection Agency to perform Special Inspections in accordance with the New York City Building Code Section 1704.10 "Wall panels, Curtain Walls, and Veneers" on the Hudson Yards Tower C located at 501 West 30<sup>th</sup> Street. Heintges & Associates confirms applicable materials utilized in the fabrication and installation of the curtain wall are in accordance with Chapter 14: Exterior Walls, Chapter 20: Aluminum, Chapter 22: Steel, and Chapter 24: Glazing of the 2008 New York City Building Code.

For inspection and testing of Welding, Fire Safing, and Concrete related to the exterior storefront and cable wall installation, refer to testing and inspection reports from the special inspection agencies who have been contracted directly by The Related Group for applicable inspections for the project.

Periodic site inspections have begun on October 16, 2015 and will remain ongoing.

The inspector has issued Site Observation Reports as required, as well as maintained the summary Special Inspections Outstanding Items List, which has been issued to the Owner and Project Team on a regular basis throughout the project. Specific reports can be made available for review as required.

Very truly yours,

HEINTGES & ASSOCIATES



John C. Pachuta, AIA