

S E R V I C E N O T E

SUPERSEDES: NONE

54124A Four Channel Test Set

54121A-02B Serials: 0000A00000 / 9999Z99999

54123A-01 Serials: 0000A00000 / US99999999

54124A-01 Serials: 0000A00000 / US99999999

TDR System Specification Change**Duplicate Service Notes:** 54121A-02B, 54123A-01, 54124A-01

The 54124A TDR System Flatness specification has changed from:

“< +5%, -3% to 1 ns from edge” to the following:

“< +5%, -5% to 1 ns from edge (measured in Low bandwidth in Averaged display mode)”

Please make this - 3% to - 5% specification change in your 54124A service manual on the following pages: 1-4, 3-24, 3-27, 3-28 and test record page 3-36.

New instruments and replacement TDR Step Generators, part number 5086-7471 and 5086-6471, now have this specification change. This specification change does not degrade measurement capability of the 54120 TDR system.

DATE: January 1996

ADMINISTRATIVE INFORMATION

SERVICE NOTE CLASSIFICATION:

INFORMATION ONLY

AUTHOR:

ENTITY:

ADDITIONAL INFORMATION:

RK

0840